



# Appendix 3 – Site requirements

Flexible Service requirement Autumn 2022

**Contents**

1 Service parameters.....3

2 Site specific requirements.....4

## 1 Service parameters

Figure 1: Service parameters

	Sustain	Secure	Dynamic	Restore
Minimum Declarable Capacity	50kW	50kW	50kW	50kW
Minimum Utilisation Duration Capability	30 mins	30 mins	30 mins	30 mins
Minimum Utilisation	30 mins	30 mins	30 mins	30 mins
Maximum Ramping Period	N/A	<15 mins	<2 mins	<2 mins
Availability Agreement Period	N/A	Contract stage	Contract stage	Contract stage
Utilisation Instruction Notification Period	Scheduled in advance	Contract stage	Real Time	Real Time
When required?	Scheduled forecast overload	Pre-fault / peak shaving	Network abnormality / planned outage	Network Abnormality
Risk to Network	Low	Medium	High	High
Utilisation Certainty	High	High	Low	Low
Frequency of Use*	High	Medium	Low	Low

## 2 Site specific requirements

Figure 2 below details the specific requirements for each of our sites. For further detail on service windows, please see Appendix 5 – Half Hourly Requirements, and for further locational details please see the our flexibility map at [www.enwl.co.uk/flexible-services](http://www.enwl.co.uk/flexible-services).

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Alston</b>	CA9 1 ,CA9 3 ,CA9 6	0.24/11kV	FY24: 1.67	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £28,983
			FY25: 1.67			FY25: Apr 24-Mar 25				FY25: 100	FY25: £28,983
			FY26: 1.67			FY26: Apr 25-Mar 26				FY26: 100	FY26: £28,983
			FY27: 1.67			FY27: Apr 26-Mar 27				FY27: 100	FY27: £28,983
			FY28: 1.67			FY28: Apr 27-Mar 28				FY28: 100	FY28: £28,983
<b>Alston</b>	CA9 1 ,CA9 3 ,CA9 6	0.24/11kV	W23/24: 0.16	Dynamic	01/10/2023	W23/24: Oct 23-Mar 24	W23/24: 08:00-18:00	W23/24: Sun, Mon, Wed, Thu, Fri, Sat	W23/24: 19	W23/24: 24	W23/24: £167,161
			S24: 0.16			S24: Apr 24-Sep 24			S24: 26	S24: 48	S24: £66,864
			W24/25: 0.24			W24/25: Oct 24-Mar 25			W24/25: 47	W24/25: 48	W24/25: £100,297
			S25:			S25:			W24/25: 08:00-	W24/25:	S25:

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
			0.19			Apr 25-Sep 25	19:00	Sun, Mon, Tue, Wed, Fri, Sat	42	48	£67,576
			W25/26: 0.28			W25/26: Oct 25-Mar 26	S25: 08:30-15:00		W25/26: 69	W25/26: 48	W25/26: £99,585
			S26: 0.28			S26: Apr 26-Sep 26	W25/26: 07:30-19:30	S25: Sun, Mon, Tue, Wed, Sat	S26: 80	S26: 48	S26: £72,008
			W26/27: 0.37			W26/27: Oct 26-Mar 27	S26: 08:00-16:00	W25/26: Everyday	W26/27: 184	W26/27: 48	W26/27: £95,153
			S27: 0.34			S27: Apr 27-Sep 27	W26/27: 07:30-20:30	S26: Sun, Mon, Tue, Wed, Thu	S27: 128	S27: 48	S27: £73,811
			W27/28: 0.43			W27/28: Oct 27-Mar 28	S27: 08:00-19:00	W26/27: Everyday	W27/28: 318	W27/28: 48	W27/28: £93,350
							W27/28: 07:30-23:30	S27: Mon, Tue, Wed, Thu, Fri			
								W27/28: Everyday			

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Ardwick</b>	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W24/25: 12.84 W25/26: 12.84 S26: 12.84 W26/27: 12.84 S27: 12.84 W27/28: 12.84	Restore	01/10/2024	W24/25: Oct 24-Mar 25 W25/26: Oct 25-Mar 26 S26: Apr 26-Sep 26 W26/27: Oct 26-Mar 27 S27: Apr 27-Sep 27 W27/28: Oct 27-Mar 28	W24/25: 00:00-23:59	W24/25: Everyday	W24/25: 100	W24/25: 100 W25/26: 100 S26: 100 W26/27: 100 S27: 100 W27/28: 100	W24/25: £89,080 W25/26: £89,080 S26: £89,080 W26/27: £89,080 S27: £89,080 W27/28: £89,080
<b>Ardwick</b>	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W23/24: 0.59 S25: 2.20	Dynamic	01/11/2023	W23/24: Nov 23-Mar 24 S25: Apr 25-Sep 25	W23/24: 10:00-21:00 S25: 09:00-23:00	W23/24: Everyday S25: Sun, Mon, Tue, Wed, Fri	W23/24: 276 S25: 73	W23/24: 48 S25: 48	W23/24: £103,898 S25: £29,267

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Ardwick</b>	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W24/25: 3.41	Secure	01/10/2024	W24/25: Oct 24-Mar 25	W24/25: 08:00-23:30	W24/25: Everyday	W24/25: 1549	W24/25: 100	W24/25: £103,898
			W25/26: 5.61			W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 2687	W25/26: 200	W25/26: £74,631
			S26: 4.07			S26: Apr 26-Sep 26	S26: 07:30-23:59	S26: Everyday	S26: 729	S26: 100	S26: £35,505
			W26/27: 7.84			W26/27: Oct 26-Mar 27	W26/27: 23:59	W26/27: Everyday	W26/27: 3413	W26/27: 300	W26/27: £68,393
			S27: 5.90			S27: Apr 27-Sep 27	W26/27: 00:00-23:59	S27: Everyday	S27: 2065	S27: 200	S27: £38,481
			W27/28: 10.03			W27/28: Oct 27-Mar 28	S27: 00:00-23:59	W27/28: Everyday	W27/28: 4177	W27/28: 400	W27/28: £65,417
						W27/28: 00:00-23:59					

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Askerton Castle</b>	CA16 6 ,CA6 4 ,CA6 6 ,CA8 2 ,CA8 7 ,PR7 7	0.24/11kV	FY24: 1.34	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £10,168
			FY25: 1.34			FY25: Apr 24-Mar 25				FY25: 100	FY25: £10,168
			FY26: 1.34			FY26: Apr 25-Mar 26				FY26: 100	FY26: £10,168
			FY27: 1.34			FY27: Apr 26-Mar 27				FY27: 100	FY27: £10,168
			FY28: 1.34			FY28: Apr 27-Mar 28				FY28: 100	FY28: £10,168
<b>Bentham</b>	BL9 0 ,BL9 7 ,L ,LA1 2 ,LA2 7 ,LA2 8 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY24: 4.49	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £48,223
			FY25: 4.49			FY25: Apr 24-Mar 25				FY25: 100	FY25: £48,223
			FY26: 4.49			FY26: Apr 25-Mar 26				FY26: 100	FY26: £48,223
			FY27: 4.49			FY27: Apr 26-Mar 27				FY27: 100	FY27: £48,223
			FY28: 4.49			FY28: Apr 27-Mar 28				FY28: 100	FY28: £48,223



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Bolton By Bowland</b>	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	FY24: 3.16	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £22,086
			FY25: 3.16			FY25: Apr 24-Mar 25				FY25: 100	FY25: £22,086
			FY26: 3.16			FY26: Apr 25-Mar 26				FY26: 100	FY26: £22,086
			FY27: 3.16			FY27: Apr 26-Mar 27				FY27: 100	FY27: £22,086
			FY28: 3.16			FY28: Apr 27-Mar 28				FY28: 100	FY28: £22,086
<b>Bolton By Bowland</b>	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	W23/24: 0.32	Dynamic	01/11/2023	W23/24: Nov 23-Mar 24	W23/24: 09:00-20:30	W23/24: Everyday	W23/24: 59	W23/24: 48	W23/24: £50,209
			W24/25: 0.46			W24/25: Nov 24-Mar 25	W24/25: 08:30-21:00	W24/25: Everyday	W24/25: 168	W24/25: 48	W24/25: £50,209
			W25/26: 0.58			W25/26: Oct 25-Mar 26	W25/26: 07:30-22:00	W25/26: Everyday	W25/26: 342	W25/26: 48	W25/26: £50,209
			W26/27: 0.70			W26/27: Oct 26-Mar 27	W26/27: 07:00-22:30	W26/27: Everyday	W26/27: 636	W26/27: 48	W26/27: £50,209

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Bolton By Bowland</b>	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	W27/28: 0.83	Secure	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 06:30-23:00	W27/28: Everyday	W27/28: 967	W27/28: 100	W27/28: £50,209
<b>Catterall Waterworks</b>	PR1 1 ,PR2 8 ,PR3 0 ,PR3 1	0.24/11kV	FY24: 7.62 FY25: 7.62 FY26: 7.62 FY27: 7.62 FY28: 7.62	Restore	01/04/2023	FY24: Apr 23-Mar 24 FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100 FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY24: £12,486 FY25: £12,486 FY26: £12,486 FY27: £12,486 FY28: £12,486

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Catterall Waterworks</b>	PR1 1 ,PR2 8 ,PR3 0 ,PR3 1	0.24/11kV	W23/24: 3.33	Dynamic	01/10/2023	W23/24: Oct 23-Mar 24	All Day	Everyday	W23/24: 3886	W23/24: 48	W23/24: £167,362
			S24: 3.32			S24: Apr 24-Sep 24			S24: 3746	S24: 48	S24: £67,231
			W24/25: 3.55			W24/25: Oct 24-Mar 25			W24/25: 4030	W24/25: 48	W24/25: £100,131
			S25: 3.32			S25: Apr 25-Sep 25			S25: 3747	S25: 48	S25: £67,231
			W25/26: 3.55			W25/26: Oct 25-Mar 26			W25/26: 4033	W25/26: 48	W25/26: £100,131
			S26: 3.34			S26: Apr 26-Sep 26			S26: 3759	S26: 48	S26: £68,339
			W26/27: 3.56			W26/27: Oct 26-Mar 27			W26/27: 4045	W26/27: 48	W26/27: £99,022
			S27: 3.43			S27: Apr 27-Sep 27			S27: 3845	S27: 48	S27: £69,834
W27/28: 3.66	W27/28: Oct 27-Mar 28	W27/28: 4138	W27/28: 48	W27/28: £97,527							

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Church</b>	BB5 0 ,BB5 1 ,BB5 2 ,BB5 4 ,BB5 5 ,BB5 6	0.24/11kV	FY24: 5.80	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £86,221
			FY25: 5.80			FY25: Apr 24-Mar 25				FY25: 100	FY25: £86,221
			FY26: 5.80			FY26: Apr 25-Mar 26				FY26: 100	FY26: £86,221
			FY27: 5.80			FY27: Apr 26-Mar 27				FY27: 100	FY27: £86,221
			FY28: 5.80			FY28: Apr 27-Mar 28				FY28: 100	FY28: £86,221
<b>Cloughton</b>	LA1 1 ,LA2 0 ,LA2 6 ,LA2 7 ,LA2 8 ,LA2 9	0.24/11kV	FY24: 4.13	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £38,332
			FY25: 4.13			FY25: Apr 24-Mar 25				FY25: 100	FY25: £38,332
			FY26: 4.13			FY26: Apr 25-Mar 26				FY26: 100	FY26: £38,332
			FY27: 4.13			FY27: Apr 26-Mar 27				FY27: 100	FY27: £38,332
			FY28: 4.13			FY28: Apr 27-Mar 28				FY28: 100	FY28: £38,332

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Coniston</b>	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	FY24: 2.41	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £28,693
			FY25: 2.41			FY25: Apr 24-Mar 25				FY25: 100	FY25: £28,693
			FY26: 2.41			FY26: Apr 25-Mar 26				FY26: 100	FY26: £28,693
			FY27: 2.41			FY27: Apr 26-Mar 27				FY27: 100	FY27: £28,693
			FY28: 2.41			FY28: Apr 27-Mar 28				FY28: 100	FY28: £28,693
<b>Coniston</b>	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	S24: 0.52	Dynamic	01/04/2024	S24: Apr 24-Sep 24	S24: 07:00-21:30	S24: Everyday	S24: 631	S24: 48	S24: £15,472
<b>Coniston</b>	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	W23/24: 0.83	Secure	01/10/2023	W23/24: Oct 23-Feb 24	W23/24: 01:00-23:59	W23/24: Everyday	W23/24: 1188	W23/24: 100	W23/24: £42,845
			W24/25: 0.92			W24/25: Oct 24-Feb 25	W24/25: 00:00-23:59	W24/25: Everyday	W24/25: 1475	W24/25: 100	W24/25: £27,373
			S25: 0.62			S25: Apr 25-Sep 25	S25: 00:00-23:59	S25: Everyday	S25: 908	S25: 100	S25: £16,002
			W25/26:			W25/26:	S25: 03:00-	W25/26:	W25/26:	W25/26:	W25/26:

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
			1.04			Oct 25-Mar 26	21:30	Everyday	1836	100	£26,842
			S26: 0.69			S26: Apr 26-Sep 26	W25/26: 00:00-23:59	S26: Everyday	S26: 1115	S26: 100	S26: £16,333
			W26/27: 1.12			W26/27: Oct 26-Mar 27	S26: 02:30-22:00	W26/27: Everyday	W26/27: 2113	W26/27: 200	W26/27: £26,512
			S27: 0.73			S27: Apr 27-Sep 27	W26/27: 00:00-23:59	S27: Everyday	S27: 1224	S27: 100	S27: £16,461
			W27/28: 1.17			W27/28: Oct 27-Mar 28	S27: 02:00-22:30	W27/28: Everyday	W27/28: 2321	W27/28: 200	W27/28: £26,383
							W27/28: 00:00-23:59				
<b>Eastlands</b>	CA13 0 ,M1 2 ,M11 3 ,M11 4 ,M3 6 ,M4 5 ,M4 6 ,M4 7 ,M40 7 ,M40 8 ,M50 3	0.24/11kV	W25/26: 1.51	Dynamic	01/11/2025	W25/26: Nov 25-Mar 26	W25/26: 16:30-22:00	W25/26: Everyday	W25/26: 59	W25/26: 48	W25/26: £37,773

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Flat Lane</b>	BB7 4 ,BD ,BD23 1 ,BD23 3 ,BD23 4 ,BD23 6 ,BD24 0 ,BD24 9 ,LA2 8	0.24/11kV	FY24: 3.92	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £43,877
			FY25: 3.92			FY25: Apr 24-Mar 25				FY25: 100	FY25: £43,877
			FY26: 3.92			FY26: Apr 25-Mar 26				FY26: 100	FY26: £43,877
			FY27: 3.92			FY27: Apr 26-Mar 27				FY27: 100	FY27: £43,877
			FY28: 3.92			FY28: Apr 27-Mar 28				FY28: 100	FY28: £43,877

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Flat Lane</b>	BB7 4 ,BD ,BD23 1 ,BD23 3 ,BD23 4 ,BD23 6 ,BD24 0 ,BD24 9 ,LA2 8	0.24/11kV	W24/25: 0.78	Dynamic	01/11/2024	W24/25: Nov 24-Feb 25	W24/25: 12:30-20:30	W24/25: Everyday	W24/25: 128	W24/25: 48	W24/25: £5,539
			W25/26: 0.94			W25/26: Nov 25-Feb 26	W25/26: 12:30-20:30	W25/26: Everyday	W25/26: 173	W25/26: 48	W25/26: £5,539
			W26/27: 1.11			W26/27: Nov 26-Mar 27	W26/27: Everyday	W26/27: 235	W26/27: 48	W26/27: £5,539	
			W27/28: 1.27			W27/28: Nov 27-Mar 28	W27/28: 08:30-21:00	W27/28: Everyday	W27/28: 290	W27/28: 48	W27/28: £5,539
							W27/28: 08:30-21:30				



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Gillsrow</b>	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA12 4 ,CA12 5 ,CA17 4 ,CA4 0 ,CA7 8 ,PR2 1	0.24/11kV	FY24: 4.67	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £38,777
			FY25: 4.67			FY25: Apr 24-Mar 25				FY25: 100	FY25: £38,777
			FY26: 4.67			FY26: Apr 25-Mar 26				FY26: 100	FY26: £38,777
			FY27: 4.67			FY27: Apr 26-Mar 27				FY27: 100	FY27: £38,777
			FY28: 4.67			FY28: Apr 27-Mar 28				FY28: 100	FY28: £38,777
<b>Helwith Bridge</b>	BD24 0 ,BD24 9 ,LA2 8 ,LA2 9 ,LA6 3	0.24/11kV	FY24: 3.11	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £18,435
			FY25: 3.11			FY25: Apr 24-Mar 25				FY25: 100	FY25: £18,435
			FY26: 3.11			FY26: Apr 25-Mar 26				FY26: 100	FY26: £18,435
			FY27: 3.11			FY27: Apr 26-Mar 27				FY27: 100	FY27: £18,435
			FY28: 3.11			FY28: Apr 27-Mar 28				FY28: 100	FY28: £18,435

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Heywood	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W25/26: 12.42	Restore	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 100	W25/26: 100	W25/26: £128,402
			S26: 12.42			S26: Apr 26-Sep 26	S26: 100		S26: £128,402		
			W26/27: 12.42			W26/27: Oct 26-Mar 27	W26/27: 100		W26/27: £128,402		
			S27: 12.42			S27: Apr 27-Sep 27	S27: 100		S27: £128,402		
			W27/28: 12.42			W27/28: Oct 27-Mar 28			W27/28: 100	W27/28: £128,402	
Heywood	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W24/25: 1.25	Dynamic	01/01/2025	W24/25: Jan 25-Mar 25	W24/25: 09:30-15:00	W24/25: Sun, Mon, Sat	W24/25: 52	W24/25: 48	W24/25: £1,615
			S25: 2.63			S25: Apr 25-Sep 25	S25: 08:30-21:30		S25: 442	S25: 48	S25: £458

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Heywood</b>	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W25/26: 6.65	Secure	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 07:00-23:30	W25/26: Everyday	W25/26: 1399	W25/26: 100	W25/26: £1,158
			S26: 11.10			S26: Apr 26-Sep 26	S26: 00:00-23:59	S26: Everyday	S26: 3131	S26: 300	S26: £646
			W26/27: 16.67			W26/27: Oct 26-Mar 27	W26/27: 00:00-23:59	W26/27: Everyday	W26/27: 3861	W26/27: 300	W26/27: £970
			S27: 13.43			S27: Apr 27-Sep 27	S27: 00:00-23:59	S27: Everyday	S27: 3428	S27: 300	S27: £660
			W27/28: 19.43			W27/28: Oct 27-Mar 28	S27: 00:00-23:59	W27/28: Everyday	W27/28: 4294	W27/28: 400	W27/28: £955
						W27/28: 00:00-23:59					

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Ingleton</b>	LA2 7 ,LA2 8 ,LA6 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY24: 2.27	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £31,668
			FY25: 2.27			FY25: Apr 24-Mar 25				FY25: 100	FY25: £31,668
			FY26: 2.27			FY26: Apr 25-Mar 26				FY26: 100	FY26: £31,668
			FY27: 2.27			FY27: Apr 26-Mar 27				FY27: 100	FY27: £31,668
			FY28: 2.27			FY28: Apr 27-Mar 28				FY28: 100	FY28: £31,668
<b>Marple</b>	SK3 9 ,SK6 2 ,SK6 4 ,SK6 5 ,SK6 6 ,SK6 7	0.24/11kV	FY24: 4.67	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £72,834
			FY25: 4.67			FY25: Apr 24-Mar 25				FY25: 100	FY25: £72,834
			FY26: 4.67			FY26: Apr 25-Mar 26				FY26: 100	FY26: £72,834
			FY27: 4.67			FY27: Apr 26-Mar 27				FY27: 100	FY27: £72,834
			FY28: 4.67			FY28: Apr 27-Mar 28				FY28: 100	FY28: £72,834

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Melling</b>	LA2 7 ,LA2 8 ,LA2 9 ,LA5 8 ,LA6 1 ,LA6 2 ,LA6 3 ,LA6 7	0.24/11kV	FY24: 2.23	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £25,119
			FY25: 2.23			FY25: Apr 24-Mar 25				FY25: 100	FY25: £25,119
			FY26: 2.23			FY26: Apr 25-Mar 26				FY26: 100	FY26: £25,119
			FY27: 2.23			FY27: Apr 26-Mar 27				FY27: 100	FY27: £25,119
			FY28: 2.23			FY28: Apr 27-Mar 28				FY28: 100	FY28: £25,119
<b>Moss Lane</b>	BB12 8 ,BL9 8 ,BL9 9 ,M ,M24 4 ,M25 1 ,M25 2 ,M25 3 ,M25 7 ,M25 9 ,M4 5 ,M45 ,M45 6 ,M45 7 ,M45 8 ,M46 7 ,M7 4 ,M8 9 ,OL10 2	0.24/11kV	W25/26: 0.71	Dynamic	01/11/2025	W25/26: Nov 25-Feb 26	W25/26: 17:00-19:30	W25/26: Sun, Mon, Tue, Wed, Sat  W26/27: Sun, Mon, Tue, Wed, Thu  W27/28: Everyday	W25/26: 29	W25/26: 48	W25/26: £145,291
			W26/27: 1.50			W26/27: Nov 26-Feb 27	W26/27: 17:00-20:00		W26/27: 86	W26/27: 48	W26/27: £145,291
			W27/28: 2.24			W27/28: Nov 27-Mar 28	W27/28: 13:00-20:00		W27/28: 169	W27/28: 48	W27/28: £145,291

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Moss Side (Longsight)</b>	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W25/26: 16.09	Restore	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 100	W25/26: 100	W25/26: £197,973
			W26/27: 16.09			W26/27: Oct 26-Mar 27				W26/27: 100	W26/27: £197,973
			S27: 16.09			S27: Apr 27-Sep 27				S27: 100	S27: £197,973
			W27/28: 16.09			W27/28: Oct 27-Mar 28				W27/28: 100	W27/28: £197,973
<b>Moss Side (Longsight)</b>	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W24/25: 2.20	Dynamic	01/10/2024	W24/25: Oct 24-Mar 25	W24/25: 11:30-22:30	W24/25: Everyday	W24/25: 418	W24/25: 48	W24/25: £8,577
			S26: 2.26			S26: Apr 26-Sep 26				S26: 186	S26: 48

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Moss Side (Longsight)</b>	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W25/26: 4.33	Secure	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 09:30-23:59	W25/26: Everyday	W25/26: 1489	W25/26: 100	W25/26: £8,577
			W26/27: 6.58			W26/27: Oct 26-Mar 27	W26/27: 00:00-23:59	W26/27: Everyday	W26/27: 2588	W26/27: 200	W26/27: £6,384
			S27: 4.16			S27: Apr 27-Sep 27	S27: Everyday	S27: 1568	S27: 100	S27: £2,738	
			W27/28: 8.87			W27/28: Oct 27-Mar 28	W27/28: 07:00-23:00	W27/28: Everyday	W27/28: 3183	W27/28: 300	W27/28: £5,839
<b>Newbiggin on Lune</b>	CA10 3 ,CA17 4 ,LA10 5	0.24/11kV	FY24: 0.91	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £12,041
			FY25: 0.91			FY25: Apr 24-Mar 25				FY25: 100	FY25: £12,041
			FY26: 0.91			FY26: Apr 25-Mar 26				FY26: 100	FY26: £12,041
			FY27: 0.91			FY27: Apr 26-Mar 27				FY27: 100	FY27: £12,041
			FY28: 0.91			FY28: Apr 27-Mar 28				FY28: 100	FY28: £12,041

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Newby</b>	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA11 9 ,CA15 6 ,CA16 ,CA16 6 ,CA17 4 ,CA20 2	0.24/11kV	FY24: 5.48  FY25: 5.48  FY26: 5.48  FY27: 5.48  FY28: 5.48	Restore	01/04/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £59,814  FY25: £59,814  FY26: £59,814  FY27: £59,814  FY28: £59,814
<b>Portwood</b>	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	W27/28: 18.25	Restore	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 00:00-23:59	W27/28: Everyday	W27/28: 100	W27/28: 100	W27/28: £68,857



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Portwood</b>	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	W25/26: 0.63	Dynamic	01/12/2025	W25/26: Dec 25-Feb 26	W25/26: 11:00-15:00	W25/26: Sun, Mon, Tue	W25/26: 23	W25/26: 24	W25/26: £8,278
			S26: 4.17			S26: Apr 26-Sep 26	S26: 08:30-17:00	S26: Sun, Mon, Tue, Wed, Thu	S26: 173	S26: 48	S26: £5,032
			W26/27: 2.69			W26/27: Oct 26-Mar 27	W26/27: 09:30-18:00	W26/27: Mon, Tue, Wed, Thu	W26/27: 292	W26/27: 48	W26/27: £3,246
			S27: 6.47			S27: Apr 27-Sep 27	S27: 08:00-18:00	S27: Everyday	S27: 615	S27: 48	S27: £4,727
<b>Portwood</b>	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	W27/28: 4.86	Secure	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 09:00-18:30	W27/28: Everyday	W27/28: 809	W27/28: 100	W27/28: £3,551

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Rossall</b>	FY7 7 ,FY7 8	0.24/11kV	FY24: 3.89	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £14,012
			FY25: 3.89			FY25: Apr 24-Mar 25				FY25: 100	FY25: £14,012
			FY26: 3.89			FY26: Apr 25-Mar 26				FY26: 100	FY26: £14,012
			FY27: 3.89			FY27: Apr 26-Mar 27				FY27: 100	FY27: £14,012
			FY28: 3.89			FY28: Apr 27-Mar 28				FY28: 100	FY28: £14,012
<b>Scarisbrick</b>	L39 3 ,L39 7 ,L39 8 ,L40 8 ,L40 9 ,PR8 ,PR8 4 ,PR8 5 ,PR8 8 ,PR9 8 ,WA4 1	0.24/11kV	FY24: 5.23	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £32,016
			FY25: 5.23			FY25: Apr 24-Mar 25				FY25: 100	FY25: £32,016
			FY26: 5.23			FY26: Apr 25-Mar 26				FY26: 100	FY26: £32,016
			FY27: 5.23			FY27: Apr 26-Mar 27				FY27: 100	FY27: £32,016
			FY28: 5.23			FY28: Apr 27-Mar 28				FY28: 100	FY28: £32,016

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Sebergham</b>	CA11 9 ,CA2 5 ,CA20 1 ,CA4 0 ,CA4 8 ,CA5 1 ,CA5 6 ,CA5 7 ,CA7 1 ,CA7 8 ,CA7 9 ,CA8 9	0.24/11kV	FY24: 3.74	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £26,240
			FY25: 3.74			FY25: Apr 24-Mar 25				FY25: 100	FY25: £26,240
			FY26: 3.74			FY26: Apr 25-Mar 26				FY26: 100	FY26: £26,240
			FY27: 3.74			FY27: Apr 26-Mar 27				FY27: 100	FY27: £26,240
			FY28: 3.74			FY28: Apr 27-Mar 28				FY28: 100	FY28: £26,240
<b>Sedbergh</b>	LA10 5 ,LA6 2 ,LA8 0 ,LA8 9	0.24/11kV	FY24: 4.19	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £52,029
			FY25: 4.19			FY25: Apr 24-Mar 25				FY25: 100	FY25: £52,029
			FY26: 4.19			FY26: Apr 25-Mar 26				FY26: 100	FY26: £52,029
			FY27: 4.19			FY27: Apr 26-Mar 27				FY27: 100	FY27: £52,029
			FY28: 4.19			FY28: Apr 27-Mar 28				FY28: 100	FY28: £52,029

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Settle</b>	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	FY24: 4.26	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £50,174
			FY25: 4.26			FY25: Apr 24-Mar 25				FY25: 100	FY25: £50,174
			FY26: 4.26			FY26: Apr 25-Mar 26				FY26: 100	FY26: £50,174
			FY27: 4.26			FY27: Apr 26-Mar 27				FY27: 100	FY27: £50,174
			FY28: 4.26			FY28: Apr 27-Mar 28				FY28: 100	FY28: £50,174

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Settle</b>	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	W23/24: 0.09	Dynamic	01/11/2023	W23/24: Nov 23-Jan 24	W23/24: 10:30-19:00	W23/24: Tue, Thu, Sat	W23/24: 12	W23/24: 24	W23/24: £40,167
			W24/25: 0.20			W24/25: Nov 24-Feb 25	W24/25: 10:00-20:30	W24/25: Sun, Mon, Thu, Sat	W24/25: 42	W24/25: 48	W24/25: £40,167
			W25/26: 0.28			W25/26: Nov 25-Mar 26	W25/26: 09:30-20:30	W25/26: Sun, Mon, Tue, Fri	W25/26: 77	W25/26: 48	W25/26: £40,167
			W26/27: 0.37			W26/27: Nov 26-Mar 27	W26/27: 09:30-20:30	W26/27: Everyday	W26/27: 149	W26/27: 48	W26/27: £40,167
			W27/28: 0.46			W27/28: Nov 27-Feb 28	W27/28: 08:30-20:30	W27/28: Everyday	W27/28: 243	W27/28: 48	W27/28: £40,167

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Victoria Park</b>	M1 6 ,M1 7 ,M13 9 ,M14 5 ,M14 6 ,M15 6 ,M2 4	0.24/11kV	S25: 4.40	Dynamic	01/04/2025	S25: Apr 25-Sep 25	S25: 00:00-16:00	S25: Sun, Mon, Tue, Sat	S25: 20	S25: 24	S25: £20,266
			S26: 6.61			S26: Apr 26-Sep 26	S26: 00:00-17:30	S26: Sun, Mon, Tue, Wed, Thu	S26: 102	S26: 48	S26: £18,201
			W26/27: 0.75			W26/27: Oct 26-Feb 27	W26/27: 10:00-18:00	W26/27: Sun, Mon, Tue, Wed, Thu	W26/27: 25	W26/27: 48	W26/27: £2,065
			S27: 4.66			S27: Apr 27-Sep 27	S27: 08:00-19:30	W26/27: Sun, Mon, Tue, Wed, Thu	S27: 307	S27: 48	S27: £7,079
			W27/28: 8.68			W27/28: Oct 27-Mar 28	W27/28: 00:00-19:30	S27: Mon, Tue, Wed, Thu, Fri	W27/28: 620	W27/28: 48	W27/28: £13,187

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)	
<b>Wigton</b>	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	W23/24: 24.17	Restore	01/10/2023	W23/24: Oct 23-Mar 24	W23/24: 00:00-23:59	W23/24: Everyday	W23/24: 100	W23/24: 100	W23/24: £122,846	
			W24/25: 24.17			W24/25: Oct 24-Mar 25				W24/25: 100	W24/25: £122,846	
			W25/26: 24.17			W25/26: Oct 25-Mar 26				W25/26: 100	W25/26: £122,846	
			W26/27: 24.17			W26/27: Oct 26-Mar 27				W26/27: 100	W26/27: £122,846	
			S27: 24.17			S27: Apr 27-Sep 27				S27: 100	S27: £122,846	
W27/28: 24.17	W27/28: Oct 27-Mar 28	W27/28: 100	W27/28: £122,846									
<b>Wigton</b>	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	S24: 2.58	Dynamic	01/04/2024	S24: Apr 24-Sep 24	S24: 00:00-20:00	S24: Everyday	S24: 332	S24: 48	S24: £8,089	
			S25: 3.00			S25: Apr 25-Sep 25				S25: 481	S25: 48	S25: £8,299
			S26: 3.30			S26: Apr 26-Sep 26				S26: 583	S26: 48	S26: £8,416
						S26: 00:00-20:30						

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Wigton</b>	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	W23/24: 2.20	Secure	01/10/2023	W23/24: Oct 23-Mar 24	W23/24: 00:00-21:30	W23/24: Everyday	W23/24: 825	W23/24: 100	W23/24: £20,223
			W24/25: 3.87			W24/25: Oct 24-Mar 25	W24/25: 08:30-22:00	W24/25: Everyday	W24/25: 1057	W24/25: 100	W24/25: £12,134
			W25/26: 4.31			W25/26: Oct 25-Mar 26	W25/26: 08:30-22:00	W25/26: Everyday	W25/26: 1212	W25/26: 100	W25/26: £11,924
			W26/27: 4.63			W26/27: Oct 26-Mar 27	W26/27: 08:30-22:00	W26/27: Everyday	W26/27: 1319	W26/27: 100	W26/27: £11,807
			S27: 3.72			S27: Apr 27-Sep 27	W26/27: 08:30-22:30	S27: Everyday	S27: 725	S27: 100	S27: £8,559
			W27/28: 5.07			W27/28: Oct 27-Mar 28	S27: 09:00-20:30	W27/28: Everyday	W27/28: 1449	W27/28: 100	W27/28: £11,664
						W27/28: 00:00-22:30					



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
<b>Yealand</b>	LA1 9 ,LA5 0 ,LA5 9 ,LA6 1 ,LA6 3 ,LA7 7	0.24/11kV	FY24: 3.36	Restore	01/04/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £25,583
			FY25: 3.36			FY25: Apr 24-Mar 25				FY25: 100	FY25: £25,583
			FY26: 3.36			FY26: Apr 25-Mar 26				FY26: 100	FY26: £25,583
			FY27: 3.36			FY27: Apr 26-Mar 27				FY27: 100	FY27: £25,583
			FY28: 3.36			FY28: Apr 27-Mar 28				FY28: 100	FY28: £25,583