

Appendix 3

Site requirements

Flexible Service requirement
Autumn 2023

1 Service parameters

	PARAMETER NAME	RESTORE	DYNAMIC	SECURE
STRUCTURE	Payment Structure	Utilisation Only	Availability and Utilisation	Availability and Utilisation
	When prices are set (procurement timescales)	At trade	At trade	At trade
AVAILABILITY	Availability Request Mechanism	N/A	Request initiated by DNO	Request initiated by DNO
	Availability Acceptance timing	N/A	At trade	At trade
	Availability Refinement timing	N/A	Week Ahead	Week Ahead
	Availability Changes Allowed	N/A	No	No
	Minimum Aggregate Unit Size	10kW	10kW	10kW
	Partial Availability Acceptance Possible	N/A	Yes	Yes
	Time Variable Availability Volumes Allowed	N/A	Yes	Yes
	Availability Payment Unit	N/A	£/MW/H	£/MW/H
	Availability Period	N/A	Settlement Periods	Settlement Periods
UTILISATION	Utilisation Payment Unit	£/MWh	£/MWh	£/MWh
	Utilisation Period	Minutes	Minutes	Minutes
	Delivery Expectation	Continuous	Continuous	Continuous
	Maximum Response Time	15 mins*	15 mins*	15 mins*
	Payments during response time?	No	No	No
	Minimum Utilisation Time	30 mins	30 mins	30 mins
	Minimum Utilisation Volume	N/A	N/A	N/A
	Utilisation Instruction Timings	Real Time	Real Time	Real Time
	Partial Utilisation Instruction possible	Yes	Yes	Yes
	Time Variable Utilisation Volumes Allowed	Yes	Yes	Yes

* Bidders should indicate where their assets can achieve faster response times than the required Maximum Response Time. Faster responses will score higher on the bid assessment.

1 Site specific requirements

Figure 2 below details the specific requirements for each of our sites. For further detail on service windows, please see Appendix 5 – Half Hourly Requirements, and for further locational details please see our flexibility map at www.enwl.co.uk/flexible-services.

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Alston	CA9 1 ,CA9 3 ,CA9 6	0.24/11kV	FY25: 1.50	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £29,720
			FY26: 1.50			FY26: Apr 25-Mar 26				FY26: 100	FY26: £29,720
			FY27: 1.50			FY27: Apr 26-Mar 27				FY27: 100	FY27: £29,720
			FY28: 1.50			FY28: Apr 27-Mar 28				FY28: 100	FY28: £29,720

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Ardwick	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W24/25: 0.72 W25/26: 1.02 W26/27: 1.48 W27/28: 1.79	Dynamic	01/12/2024	W24/25: Dec 24-Mar 25 W25/26: Nov 25-Mar 26 W26/27: Nov 26-Mar 27 W27/28: Nov 27-Mar 28	W24/25: 10:00-19:30 W25/26: 09:30-20:00 W26/27: 09:00-21:00 W27/28: 09:00-21:00	Everyday	W24/25: 54 W25/26: 110 W26/27: 270 W27/28: 414	W24/25: 48 W25/26: 48 W26/27: 48 W27/28: 48	W24/25: £230,959 W25/26: £230,959 W26/27: £230,959 W27/28: £230,959
Askerton Castle	CA16 6 ,CA6 4 ,CA6 6 ,CA8 2 ,CA8 7 ,PR7 7	0.24/11kV	FY25: 1.30 FY26: 1.30 FY27: 1.30 FY28: 1.30	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £10,410 FY26: £10,410 FY27: £10,410 FY28: £10,410

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Bentham	BL9 0 ,BL9 7 ,L ,LA1 2 ,LA2 7 ,LA2 8 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY25: 4.00 FY26: 4.00 FY27: 4.00 FY28: 4.00	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £49,759 FY26: £49,759 FY27: £49,759 FY28: £49,759
Bolton By Bowland	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	FY25: 3.00 FY26: 3.00 FY27: 3.00 FY28: 3.00	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £22,745 FY26: £22,745 FY27: £22,745 FY28: £22,745

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Bolton By Bowland	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	W25/26: 0.22 W26/27: 0.32 W27/28: 0.41	Dynamic	01/12/2025	W25/26: Dec 25-Jan 26 W26/27: Dec 26-Jan 27 W27/28: Dec 27-Jan 28	W25/26: 16:30-19:30 W26/27: 16:00-20:00 W27/28: 08:30-20:30	Everyday	W25/26: 15 W26/27: 42 W27/28: 67	W25/26: 24 W26/27: 48 W27/28: 48	W25/26: £54,537 W26/27: £54,537 W27/28: £54,537
Catterall Waterworks	PR1 1 ,PR2 8 ,PR3 0 ,PR3 1	0.24/11kV	FY25: 8.30 FY26: 8.30 FY27: 8.30 FY28: 8.30	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £14,804 FY26: £14,804 FY27: £14,804 FY28: £14,804

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Chorley South	OL5 9 ,P ,PR26 9 ,PR6 0 ,PR6 8 ,PR6 9 ,PR7 ,PR7 0 ,PR7 1 ,PR7 2 ,PR7 3 ,PR7 4 ,PR7 5 ,PR7 9	0.24/11kV	W26/27: 0.91 W27/28: 1.47	Dynamic	01/12/2026	W26/27: Dec 26-Jan 27 W27/28: Nov 27-Feb 28	W26/27: 17:00-19:00 W27/28: 16:30-19:30	Everyday	W26/27: 24 W27/28: 59	W26/27: 24 W27/28: 48	W26/27: £15,129 W27/28: £15,129
Church	BB5 0 ,BB5 1 ,BB5 2 ,BB5 4 ,BB5 5 ,BB5 6	0.24/11kV	FY25: 6.10 FY26: 6.10 FY27: 6.10 FY28: 6.10	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £86,625 FY26: £86,625 FY27: £86,625 FY28: £86,625

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Claughton	LA1 1 ,LA2 0 ,LA2 6 ,LA2 7 ,LA2 8 ,LA2 9	0.24/11kV	FY25: 3.50	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £39,158
			FY26: 3.50			FY26: Apr 25-Mar 26				FY26: 100	FY26: £39,158
			FY27: 3.50			FY27: Apr 26-Mar 27				FY27: 100	FY27: £39,158
			FY28: 3.50			FY28: Apr 27-Mar 28				FY28: 100	FY28: £39,158

Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	FY25: 2.30	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £29,760
			FY26: 2.30			FY26: Apr 25-Mar 26				FY26: 100	FY26: £29,760
			FY27: 2.30			FY27: Apr 26-Mar 27				FY27: 100	FY27: £29,760
			FY28: 2.30			FY28: Apr 27-Mar 28				FY28: 100	FY28: £29,760
			W24/25: 0.64			W24/25: Oct 24-Mar 25				W24/25: 100	W24/25: £29,760
			S25: 0.58			S25: Apr 25-Sep 25				S25: 100	S25: £29,760
			W25/26: 0.75			W25/26: Oct 25-Mar 26				W25/26: 100	W25/26: £29,760
			S26: 0.65			S26: Apr 26-Sep 26				S26: 100	S26: £29,760
			W26/27: 0.81			W26/27: Oct 26-Mar 27				W26/27: 100	W26/27: £29,760
			S27: 0.74			S27: Apr 27-Sep 27				S27: 100	S27: £29,760
W27/28: 0.92	W27/28: Oct 27-Mar 28	W27/28: 100	W27/28: £29,760								

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	S24: 0.49	Dynamic	01/04/2024	S24: Apr 24-Sep 24	S24: 01:30-22:00	Everyday	S24: 491	S24: 48	S24: £35,473

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	W24/25: 0.64	Secure	01/10/2024	W24/25: Oct 24-Mar 25	W24/25: 01:00-23:00	Everyday	W24/25: 1861	W24/25: 100	W24/25: £46,333
			S25: 0.58			S25: Apr 25-Sep 25	S25: 01:30-22:30		S25: 825	S25: 100	S25: £35,675
			W25/26: 0.75			W25/26: Oct 25-Mar 26	W25/26: 01:00-23:30		W25/26: 2374	W25/26: 200	W25/26: £46,131
			S26: 0.65			S26: Apr 26-Sep 26	W25/26: 01:00-23:30		S26: 1114	S26: 100	S26: £36,420
			W26/27: 0.81			W26/27: Oct 26-Mar 27	S26: 01:30-23:00		W26/27: 2665	W26/27: 200	W26/27: £45,386
			S27: 0.74			S27: Apr 27-Sep 27	W26/27: 01:00-23:30		S27: 1576	S27: 100	S27: £36,468
			W27/28: 0.92			W27/28: Oct 27-Mar 28	W26/27: 01:00-23:30		W27/28: 3051	W27/28: 300	W27/28: £45,338
							S27: 01:30-23:30				
							W27/28: 00:30-23:59				

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Flat Lane	BB7 4 ,BD ,BD23 1 ,BD23 3 ,BD23 4 ,BD23 6 ,BD24 0 ,BD24 9 ,LA2 8	0.24/11kV	FY25: 3.70	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £45,188
			FY26: 3.70			FY26: Apr 25-Mar 26				FY26: 100	FY26: £45,188
			FY27: 3.70			FY27: Apr 26-Mar 27				FY27: 100	FY27: £45,188
			FY28: 3.70			FY28: Apr 27-Mar 28				FY28: 100	FY28: £45,188

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Frederick Rd BSP	,ENGLA ,GU21 6 ,M15 4 ,M15 5 ,M16 6 ,M16 9 ,M20 6 ,M21 8 ,M22 5 ,M25 9 ,M3 1 ,M3 2 ,M3 3 ,M3 4 ,M3 5 ,M3 6 ,M3 7 ,M30 0 ,M30 9 ,M33 6 ,M4 3 ,M41 7 ,M5 ,M5 0 ,M5 2 ,M5 3 ,M5 4 ,M5 5 ,M5 9 ,M50 1 ,M50 2 ,M50 3 ,M6 4 ,M6 5 ,M6 6 ,M6 7 ,M6 8 ,M60 9 ,M7 ,M7	0.24/11kV	W26/27: 6.36 W27/28: 16.70	Dynamic	01/12/2026	W26/27: Dec 26-Jan 27 W27/28: Nov 27-Mar 28	W26/27: 08:30-17:00 W27/28: 07:30-19:30	Everyday	W26/27: 39 W27/28: 450	W26/27: 48 W27/28: 48	W26/27: £252,510 W27/28: £252,510

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Gillsrow	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA12 4 ,CA12 5 ,CA17 4 ,CA4 0 ,CA7 8 ,PR2 1	0.24/11kV	FY25: 3.70	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £36,932
			FY26: 3.70			FY26: Apr 25-Mar 26				FY26: 100	FY26: £36,932
			FY27: 3.70			FY27: Apr 26-Mar 27				FY27: 100	FY27: £36,932
			FY28: 3.70			FY28: Apr 27-Mar 28				FY28: 100	FY28: £36,932
Helwith Bridge	BD24 0 ,BD24 9 ,LA2 8 ,LA2 9 ,LA6 3	0.24/11kV	FY25: 3.30	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £19,060
			FY26: 3.30			FY26: Apr 25-Mar 26				FY26: 100	FY26: £19,060
			FY27: 3.30			FY27: Apr 26-Mar 27				FY27: 100	FY27: £19,060
			FY28: 3.30			FY28: Apr 27-Mar 28				FY28: 100	FY28: £19,060

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Ingleton	LA2 7 ,LA2 8 ,LA6 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY25: 2.20	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £32,597
			FY26: 2.20			FY26: Apr 25-Mar 26				FY26: 100	FY26: £32,597
			FY27: 2.20			FY27: Apr 26-Mar 27				FY27: 100	FY27: £32,597
			FY28: 2.20			FY28: Apr 27-Mar 28				FY28: 100	FY28: £32,597
Marple	SK3 9 ,SK6 2 ,SK6 4 ,SK6 5 ,SK6 6 ,SK6 7	0.24/11kV	FY25: 4.40	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £73,798
			FY26: 4.40			FY26: Apr 25-Mar 26				FY26: 100	FY26: £73,798
			FY27: 4.40			FY27: Apr 26-Mar 27				FY27: 100	FY27: £73,798
			FY28: 4.40			FY28: Apr 27-Mar 28				FY28: 100	FY28: £73,798

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Melling	LA2 7 ,LA2 8 ,LA2 9 ,LA5 8 ,LA6 1 ,LA6 2 ,LA6 3 ,LA6 7	0.24/11kV	FY25: 2.20 FY26: 2.20 FY27: 2.20 FY28: 2.20	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £25,760 FY26: £25,760 FY27: £25,760 FY28: £25,760
Moss Lane	BB12 8 ,BL9 8 ,BL9 9 ,M ,M24 4 ,M25 1 ,M25 2 ,M25 3 ,M25 7 ,M25 9 ,M4 5 ,M45 ,M45 6 ,M45 7 ,M45 8 ,M46 7 ,M7 4 ,M8 9 ,OL10 2	0.24/11kV	W26/27: 0.37 W27/28: 0.84	Dynamic	01/11/2026	W26/27: Nov 26-Jan 27 W27/28: Nov 27-Feb 28	W26/27: 17:00-19:00 W27/28: 16:30-19:30	Everyday	W26/27: 15 W27/28: 31	W26/27: 24 W27/28: 48	W26/27: £142,465 W27/28: £142,465

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Moss Side (Leyland) & Seven Stars	PR25 3 ,PR26 6 ,PR26 7, PR25 1 ,PR25 2 ,PR25 4 ,PR25 9 ,PR26 8 ,PR26 9,PR4 1 ,PR5 1 ,PR5 3 ,PR7 5 ,PR7 6	0.24/11kV	W25/26: 0.80 W26/27: 1.29 W27/28: 1.63	Dynamic	01/11/2025	W25/26: Nov 25-Jan 26 W26/27: Nov 26-Jan 27 W27/28: Nov 27-Jan 28	W25/26: 09:00-19:00 W26/27: 09:00-19:30 W27/28: 08:30-19:30	W25/26: Sun, Mon, Fri, Sat W26/27: Every Day W27/28: Every Day	W25/26: 21 W26/27: 69 W27/28: 125	W25/26: 24 W26/27: 48 W27/28: 48	W25/26: £44,302 W26/27: £44,302 W27/28: £44,302
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W24/25: 4.20 W25/26: 4.32 W26/27: 4.80 W27/28: 5.29	Restore	01/10/2024	W24/25: Oct 24-Mar 25 W25/26: Oct 25-Mar 26 W26/27: Oct 26-Mar 27 W27/28: Oct 27-Mar 28	W24/25: 00:00-23:59	Everyday	N/A	W24/25: 100 W25/26: 100 W26/27: 100 W27/28: 100	W24/25: £204,730 W25/26: £204,730 W26/27: £204,730 W27/28: £204,730

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	S24: 1.67	Dynamic	01/04/2024	S24: Apr 24-Apr 24	S24: 12:30-20:30	Everyday	S24: 45	S24: 48	S24: £2,758
			S25: 1.78			S25: Apr 25-Apr 25	S25: 12:00-20:30		S25: 53	S25: 48	S25: £2,829
			S26: 2.21			S26: Apr 26-Sep 26	S26: 11:00-21:00		S26: 80	S26: 48	S26: £3,057
			S27: 2.65			S27: Apr 27-Sep 27	S27: 10:30-22:00		S27: 145	S27: 48	S27: £3,236

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W24/25: 4.20	Secure	01/10/2024	W24/25: Oct 24-Mar 25	W24/25: 08:00-23:30	Everyday	W24/25: 1283	W24/25: 100	W24/25: £6,937
			W25/26: 4.32			W25/26: Oct 25-Mar 26	W25/26: 07:30-23:30		W25/26: 1359	W25/26: 100	W25/26: £6,866
			W26/27: 4.80			W26/27: Oct 26-Mar 27	W26/27: 07:30-23:30		W26/27: 1625	W26/27: 100	W26/27: £6,639
			W27/28: 5.29			W27/28: Oct 27-Mar 28	W27/28: 07:30-23:30		W27/28: 1896	W27/28: 100	W27/28: £6,460
Newbiggin on Lune	CA10 3 ,CA17 4 ,LA10 5	0.24/11kV	FY25: 1.10	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £12,263
			FY26: 1.10			FY26: Apr 25-Mar 26				FY26: 100	FY26: £12,263
			FY27: 1.10			FY27: Apr 26-Mar 27				FY27: 100	FY27: £12,263
			FY28: 1.10			FY28: Apr 27-Mar 28				FY28: 100	FY28: £12,263

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)	
Newby	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA11 9 ,CA15 6 ,CA16 ,CA16 6 ,CA17 4 ,CA20 2	0.24/11kV	FY25: 5.40	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £59,906	
			FY26: 5.40			FY26: Apr 25-Mar 26				FY26: 100	FY26: £59,906	
			FY27: 5.40			FY27: Apr 26-Mar 27				FY27: 100	FY27: £59,906	
			FY28: 5.40			FY28: Apr 27-Mar 28				FY28: 100	FY28: £59,906	
Peel St	BB18 5 ,BB7 1 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 9 ,BB9 6	0.24/11kV	W25/26: 0.32	Dynamic	01/11/2025	W25/26: Nov 25-Mar 26	W25/26: 10:30-18:00	Everyday	W25/26: 24	W25/26: 24	W25/26: £43,407	
			W26/27: 0.67			W26/27: Nov 26-Mar 27				W26/27: 160	W26/27: 48	W26/27: £43,407
			W27/28: 0.99			W27/28: Nov 27-Mar 28				W27/28: 386	W27/28: 48	W27/28: £43,407
						W27/28: 09:00-19:00						

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Rossall	FY7 7 ,FY7 8	0.24/11kV	FY25: 3.90 FY26: 3.90 FY27: 3.90 FY28: 3.90	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £19,474 FY26: £19,474 FY27: £19,474 FY28: £19,474
Scarisbrick	L39 3 ,L39 7 ,L39 8 ,L40 8 ,L40 9 ,PR8 ,PR8 4 ,PR8 5 ,PR8 8 ,PR9 8 ,WA4 1	0.24/11kV	FY25: 3.70 FY26: 3.70 FY27: 3.70 FY28: 3.70	Restore	01/04/2024	FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY25: £33,878 FY26: £33,878 FY27: £33,878 FY28: £33,878

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Sebergham	CA11 9 ,CA2 5 ,CA4 0 ,CA4 8 ,CA5 1 ,CA5 6 ,CA5 7 ,CA7 1 ,CA7 8 ,CA7 9 ,CA8 9	0.24/11kV	FY25: 3.80	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £27,001
			FY26: 3.80			FY26: Apr 25-Mar 26				FY26: 100	FY26: £27,001
			FY27: 3.80			FY27: Apr 26-Mar 27				FY27: 100	FY27: £27,001
			FY28: 3.80			FY28: Apr 27-Mar 28				FY28: 100	FY28: £27,001
Sedbergh	LA10 5 ,LA6 2 ,LA8 0 ,LA8 9	0.24/11kV	FY25: 4.10	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £50,311
			FY26: 4.10			FY26: Apr 25-Mar 26				FY26: 100	FY26: £50,311
			FY27: 4.10			FY27: Apr 26-Mar 27				FY27: 100	FY27: £50,311
			FY28: 4.10			FY28: Apr 27-Mar 28				FY28: 100	FY28: £50,311

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Settle	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	FY25: 4.40	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £52,064
			FY26: 4.40			FY26: Apr 25-Mar 26				FY26: 100	FY26: £52,064
			FY27: 4.40			FY27: Apr 26-Mar 27				FY27: 100	FY27: £52,064
			FY28: 4.40			FY28: Apr 27-Mar 28				FY28: 100	FY28: £52,064
Settle	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	W24/25: 0.59	Dynamic	01/11/2024	W24/25: Nov 24-Mar 25	W24/25: 08:30-19:00	Everyday	W24/25: 103	W24/25: 48	W24/25: £43,407
			W25/26: 0.69			W25/26: Nov 25-Mar 26	W25/26: 08:00-20:00		W25/26: 182	W25/26: 48	W25/26: £43,407
			W26/27: 0.80			W26/27: Nov 26-Mar 27	W26/27: 08:00-20:00		W26/27: 266	W26/27: 48	W26/27: £43,407
			W27/28: 0.89			W27/28: Nov 27-Mar 28	W27/28: 07:30-20:30		W27/28: 360	W27/28: 48	W27/28: £43,407

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Yealand	LA1 9 ,LA5 0 ,LA5 9 ,LA6 1 ,LA6 3 ,LA7 7	0.24/11kV	FY25: 3.00	Restore	01/04/2024	FY25: Apr 24-Mar 25	All Day	Everyday	N/A	FY25: 100	FY25: £26,567
			FY26: 3.00			FY26: Apr 25-Mar 26				FY26: 100	FY26: £26,567
			FY27: 3.00			FY27: Apr 26-Mar 27				FY27: 100	FY27: £26,567
			FY28: 3.00			FY28: Apr 27-Mar 28				FY28: 100	FY28: £26,567