



# Appendix 3 – Site requirements

Flexible Service requirement Spring 2023

**Contents**

1 Service parameters.....3

2 Site specific requirements.....4

## 1 Service parameters

Figure 1: Service parameters

	Sustain	Secure	Dynamic	Restore
Minimum Declarable Capacity	50kW	50kW	50kW	50kW
Minimum Utilisation Duration Capability	30 mins	30 mins	30 mins	30 mins
Minimum Utilisation	30 mins	30 mins	30 mins	30 mins
Maximum Ramping Period	N/A	<15 mins	<2 mins	<2 mins
Availability Agreement Period	N/A	Contract stage	Contract stage	Contract stage
Utilisation Instruction Notification Period	Scheduled in advance	Contract stage	Real Time	Real Time
When required?	Scheduled forecast overload	Pre-fault / peak shaving	Network abnormality / planned outage	Network Abnormality
Risk to Network	Low	Medium	High	High
Utilisation Certainty	High	High	Low	Low
Frequency of Use*	High	Medium	Low	Low

## 2 Site specific requirements

Figure 2 below details the specific requirements for each of our sites. For further detail on service windows, please see Appendix 5 – Half Hourly Requirements, and for further locational details please see the our flexibility map at [www.enwl.co.uk/flexible-services](http://www.enwl.co.uk/flexible-services).

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Alston	CA9 1 ,CA9 3 ,CA9 6	0.24/11kV	FY24: 1.67	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £28,983
			FY25: 1.67			FY25: Apr 24-Mar 25				FY25: 100	FY25: £28,983
			FY26: 1.67			FY26: Apr 25-Mar 26				FY26: 100	FY26: £28,983
			FY27: 1.67			FY27: Apr 26-Mar 27				FY27: 100	FY27: £28,983
			FY28: 1.67			FY28: Apr 27-Mar 28				FY28: 100	FY28: £28,983

Alston	CA9 1 ,CA9 3 ,CA9 6	0.24/11kV	W23/24: 0.16	Dynamic	01/11/2023	W23/24: Nov 23-Mar 24	W23/24: 08:00-18:00	W23/24: Sun, Mon, Wed, Thu, Fri, Sat	W23/24: 19	W23/24: 24	W23/24: £182,657
			S24: 0.16			S24: Apr 24-Sep 24	S24: 08:30-15:00	S24: Sun, Mon, Tue, Sat	S24: 26	S24: 48	S24: £73,063
			W24/25: 0.24			W24/25: Oct 24-Mar 25	W24/25: 08:00-19:00	W24/25: Sun, Mon, Tue, Wed, Fri, Sat	W24/25: 47	W24/25: 48	W24/25: £109,594
			S25: 0.19			S25: Apr 25-Sep 25	S25: 08:30-15:00	S25: Sun, Mon, Tue, Wed, Fri, Sat	S25: 42	S25: 48	S25: £73,840
			W25/26: 0.28			W25/26: Oct 25-Mar 26	W25/26: 07:30-19:30	W25/26: Sun, Mon, Tue, Wed, Sat	W25/26: 69	W25/26: 48	W25/26: £108,817
			W26/27: 0.37			W26/27: Oct 26-Mar 27	W26/27: 07:30-20:30	W26/27: Tue, Wed, Sat	W26/27: 184	W26/27: 48	W26/27: £182,657
			S27: 0.34			S27: Apr 27-Sep 27	S27: 08:00-19:00	W25/26: Everyday	S27: 128	S27: 48	S27: £80,654
			W27/28: 0.43			W27/28: Oct 27-Mar 28	W27/28: 07:30-23:30	W26/27: Everyday	W27/28: 318	W27/28: 48	W27/28: £102,004
								S27: Mon, Tue, Wed, Thu, Fri			
								W27/28: Everyday			

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Ardwick	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W24/25: 12.84 W25/26: 12.84 W26/27: 12.84 S27: 12.84 W27/28: 12.84	Restore	01/10/2024	W24/25: Oct 24-Mar 25 W25/26: Oct 25-Mar 26 W26/27: Oct 26-Mar 27 S27: Apr 27-Sep 27 W27/28: Oct 27-Mar 28	W24/25: 00:00-23:59	W24/25: Everyday	W24/25: 100	W24/25: 100 W25/26: 100 W26/27: 100 S27: 100 W27/28: 100	W24/25: £89,080 W25/26: £89,080 W26/27: £89,080 S27: £89,080 W27/28: £89,080
Ardwick	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W23/24: 0.50 S25: 2.12 S26: 3.99	Dynamic	01/11/2023	W23/24: Nov 23-Feb 24 S25: Apr 25-Sep 25 S26: Apr 26-Sep 26	W23/24: 10:00-21:00 S25: 09:00-23:00 S26: 07:30-23:59	W23/24: Everyday S25: Sun, Mon, Tue, Wed, Fri S26: Everyday	W23/24: 223 S25: 65 S26: 690	W23/24: 48 S25: 48 S26: 48	W23/24: £105,605 S25: £29,343 S26: £35,922

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Ardwick	M1 2 ,M1 6 ,M1 7 ,M12 4 ,M12 5 ,M12 6 ,M13 ,M13 0 ,M13 9 ,M14 4 ,M14 5 ,M15 4 ,M15 6 ,M19 9 ,M4 1 ,M60 7	0.24/11kV	W24/25: 3.32	Secure	01/10/2024	W24/25: Oct 24-Mar 25	W24/25: 08:30-23:30	W24/25: Everyday	W24/25: 1492	W24/25: 100	W24/25: £105,605
			W25/26: 5.51			W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 2661	W25/26: 200	W25/26: £76,263
			W26/27: 7.74			W26/27: Oct 26-Mar 27	W26/27: 00:00-23:59	W26/27: Everyday	W26/27: 3383	W26/27: 300	W26/27: £69,683
			S27: 5.82			S27: Apr 27-Sep 27	S27: 00:00-23:59	S27: Everyday	S27: 2019	S27: 200	S27: £39,024
			W27/28: 9.93			W27/28: Oct 27-Mar 28	S27: 00:00-23:59	W27/28: Everyday	W27/28: 4155	W27/28: 400	W27/28: £66,582
						W27/28: 00:00-23:59					

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Askerton Castle	CA16 6 ,CA6 4 ,CA6 6 ,CA8 2 ,CA8 7 ,PR7 7	0.24/11kV	FY24: 1.34	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £10,168
			FY25: 1.34			FY25: Apr 24-Mar 25				FY25: 100	FY25: £10,168
			FY26: 1.34			FY26: Apr 25-Mar 26				FY26: 100	FY26: £10,168
			FY27: 1.34			FY27: Apr 26-Mar 27				FY27: 100	FY27: £10,168
			FY28: 1.34			FY28: Apr 27-Mar 28				FY28: 100	FY28: £10,168
Bentham	BL9 0 ,BL9 7 ,L ,LA1 2 ,LA2 7 ,LA2 8 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY24: 4.49	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £48,223
			FY25: 4.49			FY25: Apr 24-Mar 25				FY25: 100	FY25: £48,223
			FY26: 4.49			FY26: Apr 25-Mar 26				FY26: 100	FY26: £48,223
			FY27: 4.49			FY27: Apr 26-Mar 27				FY27: 100	FY27: £48,223
			FY28: 4.49			FY28: Apr 27-Mar 28				FY28: 100	FY28: £48,223



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Bolton By Bowland	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	FY24: 3.16	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £22,086
			FY25: 3.16			FY25: Apr 24-Mar 25				FY25: 100	FY25: £22,086
			FY26: 3.16			FY26: Apr 25-Mar 26				FY26: 100	FY26: £22,086
			FY27: 3.16			FY27: Apr 26-Mar 27				FY27: 100	FY27: £22,086
			FY28: 3.16			FY28: Apr 27-Mar 28				FY28: 100	FY28: £22,086
Bolton By Bowland	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	W23/24: 0.30	Dynamic	01/11/2023	W23/24: Nov 23-Mar 24	W23/24: 09:00-20:30	W23/24: Everyday	W23/24: 51	W23/24: 48	W23/24: £50,209
			W24/25: 0.44			W24/25: Nov 24-Mar 25	W24/25: 08:30-21:00	W24/25: Everyday	W24/25: 146	W24/25: 48	W24/25: £50,209
			W25/26: 0.56			W25/26: Oct 25-Mar 26	W25/26: 07:30-21:30	W25/26: Everyday	W25/26: 311	W25/26: 48	W25/26: £50,209
			W26/27: 0.68			W26/27: Oct 26-Mar 27	W26/27: 07:00-22:30	W26/27: Everyday	W26/27: 585	W26/27: 48	W26/27: £50,209

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Bolton By Bowland	BB5 2 ,BB7 2 ,BB7 3 ,BB7 4 ,BB7 6 ,BD23 3 ,BD23 4	0.24/11kV	W27/28: 0.81	Secure	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 06:30-23:00	W27/28: Everyday	W27/28: 919	W27/28: 100	W27/28: £50,209
Catterall Waterworks	PR1 1 ,PR2 8 ,PR3 0 ,PR3 1	0.24/11kV	FY24: 7.62 FY25: 7.62 FY26: 7.62 FY27: 7.62 FY28: 7.62	Restore	01/11/2023	FY24: Apr 23-Mar 24 FY25: Apr 24-Mar 25 FY26: Apr 25-Mar 26 FY27: Apr 26-Mar 27 FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100 FY25: 100 FY26: 100 FY27: 100 FY28: 100	FY24: £12,486 FY25: £12,486 FY26: £12,486 FY27: £12,486 FY28: £12,486

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Church	BB5 0 ,BB5 1 ,BB5 2 ,BB5 4 ,BB5 5 ,BB5 6	0.24/11kV	FY24: 5.80	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £86,221
			FY25: 5.80			FY25: Apr 24-Mar 25				FY25: 100	FY25: £86,221
			FY26: 5.80			FY26: Apr 25-Mar 26				FY26: 100	FY26: £86,221
			FY27: 5.80			FY27: Apr 26-Mar 27				FY27: 100	FY27: £86,221
			FY28: 5.80			FY28: Apr 27-Mar 28				FY28: 100	FY28: £86,221
Claughton	LA1 1 ,LA2 0 ,LA2 6 ,LA2 7 ,LA2 8 ,LA2 9	0.24/11kV	FY24: 4.13	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £38,332
			FY25: 4.13			FY25: Apr 24-Mar 25				FY25: 100	FY25: £38,332
			FY26: 4.13			FY26: Apr 25-Mar 26				FY26: 100	FY26: £38,332
			FY27: 4.13			FY27: Apr 26-Mar 27				FY27: 100	FY27: £38,332
			FY28: 4.13			FY28: Apr 27-Mar 28				FY28: 100	FY28: £38,332

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	FY24: 2.41  FY25: 2.41  FY26: 2.41  FY27: 2.41  FY28: 2.41	Restore	01/11/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £28,693  FY25: £28,693  FY26: £28,693  FY27: £28,693  FY28: £28,693
Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	S24: 0.51	Dynamic	01/04/2024	S24: Apr 24-Sep 24	S24: 07:00-21:30	S24: Everyday	S24: 589	S24: 48	S24: £23,505

Coniston	LA12 8 ,LA20 6 ,LA20 8 ,LA21 3 ,LA21 8 ,LA22 0 ,LA22 9	0.24/11kV	W23/24: 0.56	Secure	01/11/2023	W23/24: Nov 23-Feb 24	W23/24: 01:00- 23:59	W23/24: Everyday	W23/24: 780	W23/24: 100	W23/24: £65,445
			W24/25: 0.91			W24/25: Oct 24-Feb 25	W24/25: 00:00- 23:59	W24/25: Everyday	W24/25: 1426	W24/25: 100	W24/25: £41,940
			S25: 0.60			S25: Apr 25-Sep 25	S25: 03:00- 21:30	S25: Everyday	S25: 865	S25: 100	S25: £24,239
			W25/26: 1.02			W25/26: Oct 25-Mar 26	W25/26: 00:00- 23:59	W25/26: Everyday	W25/26: 1080	W25/26: 100	W25/26: £24,773
			S26: 0.67			S26: Apr 26-Sep 26	W26/27: Oct 26-Mar 27	W26/27: Everyday	W26/27: 2048	W26/27: 200	W26/27: £40,672
			W26/27: 1.10			W26/27: Oct 26-Mar 27	S26: 02:30- 22:00	S26: Everyday	S26: 1190	S26: 100	S26: £25,064
			S27: 0.72			S27: Apr 27-Sep 27	W27/28: Oct 27-Mar 28	W27/28: Everyday	W27/28: 2251	W27/28: 200	W27/28: £40,381
			W27/28: 1.16			W27/28: Oct 27-Mar 28	S27: 02:30- 22:00	S27: Everyday			
							W27/28: 00:00- 23:59				

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Eastlands	CA13 0 ,M1 2 ,M11 3 ,M11 4 ,M3 6 ,M4 5 ,M4 6 ,M4 7 ,M40 7 ,M40 8 ,M50 3	0.24/11kV	W25/26: 2.13	Dynamic	01/11/2025	W25/26: Nov 25-Mar 26	W25/26: 14:30-22:30	W25/26: Everyday	W25/26: 135	W25/26: 48	W25/26: £75,976
			S26: 2.87			S26: Apr 26-Apr 26	S26: 10:00-22:00	S26: Sun, Mon, Wed, Thu, Fri, Sat	S26: 64	S26: 48	S26: £22,690
			S27: 6.85			S27: Apr 27-Sep 27	S27: 00:00-23:59	S27: Everyday	S27: 360	S27: 48	S27: £28,611
Eastlands	CA13 0 ,M1 2 ,M11 3 ,M11 4 ,M3 6 ,M4 5 ,M4 6 ,M4 7 ,M40 7 ,M40 8 ,M50 3	0.24/11kV	W26/27: 6.74	Secure	01/10/2026	W26/27: Oct 26-Mar 27	W26/27: 00:00-23:59	W26/27: Everyday	W26/27: 1494	W26/27: 100	W26/27: £53,286
			W27/28: 11.34			W27/28: Oct 27-Mar 28	W27/28: 00:00-23:59	W27/28: Everyday	W27/28: 3004	W27/28: 300	W27/28: £47,365

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)	
Flat Lane	BB7 4 ,BD ,BD23 1 ,BD23 3 ,BD23 4 ,BD23 6 ,BD24 0 ,BD24 9 ,LA2 8	0.24/11kV	FY24: 3.92	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £43,877	
			FY25: 3.92			FY25: Apr 24-Mar 25				FY25: 100	FY25: £43,877	
			FY26: 3.92			FY26: Apr 25-Mar 26				FY26: 100	FY26: £43,877	
			FY27: 3.92			FY27: Apr 26-Mar 27				FY27: 100	FY27: £43,877	
			FY28: 3.92			FY28: Apr 27-Mar 28				FY28: 100	FY28: £43,877	
Flat Lane	BB7 4 ,BD ,BD23 1 ,BD23 3 ,BD23 4 ,BD23 6 ,BD24 0 ,BD24 9 ,LA2 8	0.24/11kV	W24/25: 0.57	Dynamic	01/12/2024	W24/25: Dec 24-Feb 25	W24/25: 14:00-20:00	W24/25: Everyday	W24/25: 76	W24/25: 48	W24/25: £5,539	
			W25/26: 0.73			W25/26: Dec 25-Feb 26				W25/26: 114	W25/26: 48	W25/26: £5,539
			W26/27: 0.90			W26/27: Nov 26-Feb 27				W26/27: 158	W26/27: 48	W26/27: £5,539
			W27/28: 1.06			W27/28: Nov 27-Mar 28				W27/28: 220	W27/28: 48	W27/28: £5,539
						W27/28: 08:30-21:00						

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Gillsrow	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA12 4 ,CA12 5 ,CA17 4 ,CA4 0 ,CA7 8 ,PR2 1	0.24/11kV	FY24: 4.67  FY25: 4.67  FY26: 4.67  FY27: 4.67  FY28: 4.67	Restore	01/11/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £38,777  FY25: £38,777  FY26: £38,777  FY27: £38,777  FY28: £38,777
Hattersley	SK ,SK13 1 ,SK13 5 ,SK13 6 ,SK14 1 ,SK14 2 ,SK14 3 ,SK14 5 ,SK14 6 ,SK14 8 ,SK15 1 ,SK15 2 ,SK15 3	0.24/11kV	W25/26: 0.98  W26/27: 1.46  W27/28: 1.90	Dynamic	01/12/2025	W25/26: Dec 25-Jan 26  W26/27: Dec 26-Feb 27  W27/28: Nov 27-Feb 28	W25/26: 17:30-19:30  W26/27: 17:00-20:00  W27/28: 17:00-20:00	W25/26: Sun, Mon, Thu, Fri, Sat  W26/27: Everyday  W27/28: Everyday	W25/26: 15  W26/27: 34  W27/28: 55	W25/26: 24  W26/27: 48  W27/28: 48	W25/26: £32,365  W26/27: £32,365  W27/28: £32,365



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Helwith Bridge	BD24 0 ,BD24 9 ,LA2 8 ,LA2 9 ,LA6 3	0.24/11kV	FY24: 3.11	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £18,435
			FY25: 3.11			FY25: Apr 24-Mar 25				FY25: 100	FY25: £18,435
			FY26: 3.11			FY26: Apr 25-Mar 26				FY26: 100	FY26: £18,435
			FY27: 3.11			FY27: Apr 26-Mar 27				FY27: 100	FY27: £18,435
			FY28: 3.11			FY28: Apr 27-Mar 28				FY28: 100	FY28: £18,435
Heywood	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W25/26: 12.42	Restore	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 100	W25/26: 100	W25/26: £128,402
			S26: 12.42			S26: Apr 26-Sep 26				S26: 100	S26: £128,402
			W26/27: 12.42			W26/27: Oct 26-Mar 27				W26/27: 100	W26/27: £128,402
			S27: 12.42			S27: Apr 27-Sep 27				S27: 100	S27: £128,402
			W27/28: 12.42			W27/28: Oct 27-Mar 28				W27/28: 100	W27/28: £128,402

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Heywood	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W24/25: 1.43 S25: 2.79	Dynamic	01/01/2025	W24/25: Jan 25-Mar 25 S25: Apr 25-Sep 25	W24/25: 09:30-15:30 S25: 08:00-21:30	W24/25: Sun, Mon, Sat S25: Sun, Mon, Tue, Fri, Sat	W24/25: 64 S25: 485	W24/25: 48 S25: 48	W24/25: £1,615 S25: £468
Heywood	BL9 6 ,BL9 7 ,M24 6 ,OL ,OL10 1 ,OL10 2 ,OL10 4	0.24/11kV	W25/26: 6.84 S26: 11.26 W26/27: 16.86 S27: 13.59 W27/28: 19.62	Secure	01/10/2025	W25/26: Oct 25-Mar 26 S26: Apr 26-Sep 26 W26/27: Oct 26-Mar 27 S27: Apr 27-Sep 27 W27/28: Oct 27-Mar 28	W25/26: 07:00-23:30 S26: 00:00-23:59 W26/27: 00:00-23:59 S27: 00:00-23:59 W27/28: 00:00-23:59	W25/26: Everyday S26: Everyday W26/27: Everyday S27: Everyday W27/28: Everyday	W25/26: 1467 S26: 3144 W26/27: 3891 S27: 3449 W27/28: 4325	W25/26: 100 S26: 300 W26/27: 300 S27: 300 W27/28: 400	W25/26: £1,147 S26: £647 W26/27: £968 S27: £661 W27/28: £954

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Ingleton	LA2 7 ,LA2 8 ,LA6 ,LA6 1 ,LA6 2 ,LA6 3	0.24/11kV	FY24: 2.27	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £31,668
			FY25: 2.27			FY25: Apr 24-Mar 25				FY25: 100	FY25: £31,668
			FY26: 2.27			FY26: Apr 25-Mar 26				FY26: 100	FY26: £31,668
			FY27: 2.27			FY27: Apr 26-Mar 27				FY27: 100	FY27: £31,668
			FY28: 2.27			FY28: Apr 27-Mar 28				FY28: 100	FY28: £31,668
Marple	SK3 9 ,SK6 2 ,SK6 4 ,SK6 5 ,SK6 6 ,SK6 7	0.24/11kV	FY24: 4.67	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £72,834
			FY25: 4.67			FY25: Apr 24-Mar 25				FY25: 100	FY25: £72,834
			FY26: 4.67			FY26: Apr 25-Mar 26				FY26: 100	FY26: £72,834
			FY27: 4.67			FY27: Apr 26-Mar 27				FY27: 100	FY27: £72,834
			FY28: 4.67			FY28: Apr 27-Mar 28				FY28: 100	FY28: £72,834

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Melling	LA2 7 ,LA2 8 ,LA2 9 ,LA5 8 ,LA6 1 ,LA6 2 ,LA6 3 ,LA6 7	0.24/11kV	FY24: 2.23  FY25: 2.23  FY26: 2.23  FY27: 2.23  FY28: 2.23	Restore	01/11/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £25,119  FY25: £25,119  FY26: £25,119  FY27: £25,119  FY28: £25,119
Moss Lane	BB12 8 ,BL9 8 ,BL9 9 ,M ,M24 4 ,M25 1 ,M25 2 ,M25 3 ,M25 7 ,M25 9 ,M4 5 ,M45 ,M45 6 ,M45 7 ,M45 8 ,M46 7 ,M7 4 ,M8 9 ,OL10 2	0.24/11kV	W25/26: 0.54  W26/27: 1.33  W27/28: 2.07	Dynamic	01/11/2025	W25/26: Nov 25-Feb 26  W26/27: Nov 26-Feb 27  W27/28: Nov 27-Mar 28	W25/26: 17:30-19:00  W26/27: 17:00-20:00  W27/28: 13:00-20:00	W25/26: Sun, Mon, Tue, Wed, Sat  W26/27: Sun, Mon, Tue, Wed, Thu  W27/28: Everyday	W25/26: 18  W26/27: 75  W27/28: 150	W25/26: 24  W26/27: 48  W27/28: 48	W25/26: £145,291  W26/27: £145,291  W27/28: £145,291

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W25/26: 16.09	Restore	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 00:00-23:59	W25/26: Everyday	W25/26: 100	W25/26: 100	W25/26: £197,973
			W26/27: 16.09			W26/27: Oct 26-Mar 27				W26/27: 100	W26/27: £197,973
			S27: 16.09			S27: Apr 27-Sep 27				S27: 100	S27: £197,973
			W27/28: 16.09			W27/28: Oct 27-Mar 28				W27/28: 100	W27/28: £197,973
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W24/25: 1.30	Dynamic	01/11/2024	W24/25: Nov 24-Feb 25	W24/25: 13:30-21:00	W24/25: Everyday	W24/25: 128	W24/25: 48	W24/25: £9,358
			S26: 1.51			S26: Apr 26-Sep 26				S26: 59	S26: 48

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Moss Side (Longsight)	M14 4 ,M14 5 ,M14 7 ,M15 ,M15 1 ,M15 4 ,M15 5 ,M15 6 ,M16 0 ,M16 7 ,M16 8 ,M16 9 ,M3 4 ,M40 0 ,OL6 7	0.24/11kV	W25/26: 3.43	Secure	01/10/2025	W25/26: Oct 25-Mar 26	W25/26: 10:30-23:30	W25/26: Everyday	W25/26: 989	W25/26: 100	W25/26: £9,358
			W26/27: 5.69			W26/27: Oct 26-Mar 27	W26/27: 00:00-23:59	W26/27: Everyday	W26/27: 2243	W26/27: 200	W26/27: £7,395
			S27: 3.41			S27: Apr 27-Sep 27	S27: Everyday	S27: 855	S27: 100	S27: £2,804	
			W27/28: 7.97			W27/28: Oct 27-Mar 28	W27/28: 09:00-23:00	W27/28: Everyday	W27/28: 2979	W27/28: 200	W27/28: £6,554
Newbiggin on Lune	CA10 3 ,CA17 4 ,LA10 5	0.24/11kV	FY24: 0.91	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £12,041
			FY25: 0.91			FY25: Apr 24-Mar 25				FY25: 100	FY25: £12,041
			FY26: 0.91			FY26: Apr 25-Mar 26				FY26: 100	FY26: £12,041
			FY27: 0.91			FY27: Apr 26-Mar 27				FY27: 100	FY27: £12,041
			FY28: 0.91			FY28: Apr 27-Mar 28				FY28: 100	FY28: £12,041

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Newby	CA10 1 ,CA10 2 ,CA10 3 ,CA11 0 ,CA11 9 ,CA15 6 ,CA16 ,CA16 6 ,CA17 4 ,CA20 2	0.24/11kV	FY24: 5.48	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £59,814
			FY25: 5.48			FY25: Apr 24-Mar 25				FY25: 100	FY25: £59,814
			FY26: 5.48			FY26: Apr 25-Mar 26				FY26: 100	FY26: £59,814
			FY27: 5.48			FY27: Apr 26-Mar 27				FY27: 100	FY27: £59,814
			FY28: 5.48			FY28: Apr 27-Mar 28				FY28: 100	FY28: £59,814
Portwood	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	S27: 18.25	Restore	01/04/2027	S27: Apr 27-Sep 27	S27: 00:00-23:59	S27: Everyday	S27: 100	S27: 100	S27: £68,857
			W27/28: 18.25			W27/28: Oct 27-Mar 28				W27/28: 100	W27/28: £68,857

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Portwood	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	W25/26: 1.15 S26: 4.71 W26/27: 3.21	Dynamic	01/11/2025	W25/26: Nov 25-Feb 26 S26: Apr 26-Sep 26 W26/27: Oct 26-Mar 27	W25/26: 10:30-16:00 S26: 08:30-17:30 W26/27: 09:30-18:00	W25/26: Sun, Mon, Tue S26: Sun, Mon, Tue, Wed, Thu W26/27: Mon, Tue, Wed, Thu, Sat	W25/26: 73 S26: 262 W26/27: 400	W25/26: 48 S26: 48 W26/27: 48	W25/26: £9,031 S26: £5,371 W26/27: £3,660
Portwood	SK1 0 ,SK1 1 ,SK1 2 ,SK1 3 ,SK1 4 ,SK1 8 ,SK14 5 ,SK2 6 ,SK3 0 ,SK3 8 ,SK3 9 ,SK4 1 ,SK5 7 ,SK8 5	0.24/11kV	S27: 7.02 W27/28: 5.38	Secure	01/04/2027	S27: Apr 27-Sep 27 W27/28: Oct 27-Mar 28	S27: 08:00-18:00 W27/28: 08:30-18:30	S27: Everyday W27/28: Everyday	S27: 800 W27/28: 945	S27: 100 W27/28: 100	S27: £5,113 W27/28: £3,918



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Queens Park	M4 4 ,M40 1 ,M40 2 ,M40 7 ,M40 8 ,M8 0 ,M8 5 ,M8 8 ,M9 5 ,M9 8	0.24/11kV	W24/25: 2.53 W25/26: 8.18 W26/27: 14.15 S27: 3.16	Dynamic	01/10/2024	W24/25: Oct 24-Oct 24 W25/26: Oct 25-Feb 26 W26/27: Oct 26-Mar 27 S27: Apr 27-Sep 27	W24/25: 08:00-21:30 W25/26: 00:00-23:59 W26/27: 00:00-23:59 S27: 08:30-17:00	W24/25: Fri W25/26: Sun, Wed, Sat W26/27: Sun, Mon, Tue, Wed, Thu S27: Mon, Tue, Wed, Thu, Fri	W24/25: 15 W25/26: 29 W26/27: 296 S27: 248	W24/25: 24 W25/26: 48 W26/27: 48 S27: 48	W24/25: £58,483 W25/26: £58,483 W26/27: £58,483 S27: £8,025
Queens Park	M4 4 ,M40 1 ,M40 2 ,M40 7 ,M40 8 ,M8 0 ,M8 5 ,M8 8 ,M9 5 ,M9 8	0.24/11kV	W27/28: 19.87	Secure	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 00:00-23:59	W27/28: Everyday	W27/28: 1130	W27/28: 100	W27/28: £50,458

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Rossall	FY7 7 ,FY7 8	0.24/11kV	FY24: 3.89  FY25: 3.89  FY26: 3.89  FY27: 3.89  FY28: 3.89	Restore	01/11/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £14,012  FY25: £14,012  FY26: £14,012  FY27: £14,012  FY28: £14,012
Scarisbrick	L39 3 ,L39 7 ,L39 8 ,L40 8 ,L40 9 ,PR8 ,PR8 4 ,PR8 5 ,PR8 8 ,PR9 8 ,WA4 1	0.24/11kV	FY24: 5.23  FY25: 5.23  FY26: 5.23  FY27: 5.23  FY28: 5.23	Restore	01/11/2023	FY24: Apr 23-Mar 24  FY25: Apr 24-Mar 25  FY26: Apr 25-Mar 26  FY27: Apr 26-Mar 27  FY28: Apr 27-Mar 28	All Day	Everyday	N/A	FY24: 100  FY25: 100  FY26: 100  FY27: 100  FY28: 100	FY24: £32,016  FY25: £32,016  FY26: £32,016  FY27: £32,016  FY28: £32,016

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Sebergham	CA11 9 ,CA2 5 ,CA20 1 ,CA4 0 ,CA4 8 ,CA5 1 ,CA5 6 ,CA5 7 ,CA7 1 ,CA7 8 ,CA7 9 ,CA8 9	0.24/11kV	FY24: 3.74	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £26,240
			FY25: 3.74			FY25: Apr 24-Mar 25				FY25: 100	FY25: £26,240
			FY26: 3.74			FY26: Apr 25-Mar 26				FY26: 100	FY26: £26,240
			FY27: 3.74			FY27: Apr 26-Mar 27				FY27: 100	FY27: £26,240
			FY28: 3.74			FY28: Apr 27-Mar 28				FY28: 100	FY28: £26,240
Sedbergh	LA10 5 ,LA6 2 ,LA8 0 ,LA8 9	0.24/11kV	FY24: 4.19	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £52,029
			FY25: 4.19			FY25: Apr 24-Mar 25				FY25: 100	FY25: £52,029
			FY26: 4.19			FY26: Apr 25-Mar 26				FY26: 100	FY26: £52,029
			FY27: 4.19			FY27: Apr 26-Mar 27				FY27: 100	FY27: £52,029
			FY28: 4.19			FY28: Apr 27-Mar 28				FY28: 100	FY28: £52,029

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Settle	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	FY24: 4.26	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £50,174
			FY25: 4.26			FY25: Apr 24-Mar 25				FY25: 100	FY25: £50,174
			FY26: 4.26			FY26: Apr 25-Mar 26				FY26: 100	FY26: £50,174
			FY27: 4.26			FY27: Apr 26-Mar 27				FY27: 100	FY27: £50,174
			FY28: 4.26			FY28: Apr 27-Mar 28				FY28: 100	FY28: £50,174

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Settle	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	W23/24: 0.44	Dynamic	01/11/2023	W23/24: Nov 23-Feb 24	W23/24: 09:30-20:30	W23/24: Everyday	W23/24: 223	W23/24: 48	W23/24: £42,975
			W24/25: 0.55			W24/25: Nov 24-Mar 25	W24/25: 08:30-20:30	W24/25: Everyday	W24/25: 355	W24/25: 48	W24/25: £42,975
			W25/26: 0.63			W25/26: Oct 25-Mar 26	W25/26: 08:30-21:30	W25/26: Everyday	W25/26: 465	W25/26: 48	W25/26: £42,975
			W26/27: 0.72			W26/27: Oct 26-Mar 27	W26/27: 08:00-21:30	W26/27: Mon, Tue	W26/27: 584	W26/27: 48	W26/27: £42,975
			S27: 0.34			S27: May 27-Aug 27	S27: 07:30-20:00	S27: 15	S27: 24	S27: £12,706	
Settle	BD24 0 ,BD24 4 ,BD24 9 ,LA2 8	0.24/11kV	W27/28: 0.81	Secure	01/10/2027	W27/28: Oct 27-Mar 28	W27/28: 07:30-21:30	W27/28: Everyday	W27/28: 772	W27/28: 100	W27/28: £30,269

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Victoria Park	M1 6 ,M1 7 ,M13 9 ,M14 5 ,M14 6 ,M15 6 ,M2 4	0.24/11kV	S26: 5.87  S27: 4.03  W27/28: 7.94	Dynamic	01/04/2026	S26: Apr 26-Sep 26  S27: Apr 27-Sep 27  W27/28: Oct 27-Mar 28	S26: 00:00-17:00  S27: 08:00-19:00  W27/28: 00:00-19:00	S26: Sun, Mon, Tue, Wed, Thu  S27: Mon, Tue, Wed, Thu, Fri  W27/28: Sun, Mon, Tue, Wed, Thu, Fri	S26: 59  S27: 221  W27/28: 320	S26: 48  S27: 48  W27/28: 48	S26: £20,266  S27: £6,823  W27/28: £13,443

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Wigton	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	W23/24: 24.17 W24/25: 24.17 W25/26: 24.17 W26/27: 24.17 S27: 24.17 W27/28: 24.17	Restore	01/11/2023	W23/24: Nov 23-Mar 24 W24/25: Oct 24-Mar 25 W25/26: Oct 25-Mar 26 W26/27: Oct 26-Mar 27 S27: Apr 27-Sep 27 W27/28: Oct 27-Mar 28	W23/24: 00:00-23:59	W23/24: Everyday	W23/24: 100	W23/24: 100 W24/25: 100 W25/26: 100 W26/27: 100 S27: 100 W27/28: 100	W23/24: £122,846 W24/25: £122,846 W25/26: £122,846 W26/27: £122,846 S27: £122,846 W27/28: £122,846
Wigton	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	S24: 2.64 S25: 3.06 S26: 3.36	Dynamic	01/04/2024	S24: Apr 24-Sep 24 S25: Apr 25-Sep 25 S26: Apr 26-Sep 26	S24: 00:00-20:00 S25: 00:00-20:00 S26: 00:00-20:30	S24: Everyday S25: Everyday S26: Everyday	S24: 354 S25: 502 S26: 606	S24: 48 S25: 48 S26: 48	S24: £9,242 S25: £9,472 S26: £9,612

Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Wigton	CA1 3 ,CA15 6 ,CA16 6 ,CA19 1 ,CA3 8 ,CA4 8 ,CA5 3 ,CA5 5 ,CA5 6 ,CA5 7 ,CA6 4 ,CA6 5 ,CA6 6 ,CA7 0 ,CA7 1 ,CA7 2 ,CA7 3 ,CA7 4 ,CA7 5 ,CA7 8 ,CA7 9	0.24/11kV	W23/24: 2.26	Secure	01/11/2023	W23/24: Nov 23-Mar 24	W23/24: 00:00- 21:30	W23/24: Everyday	W23/24: 839	W23/24: 100	W23/24: £22,999
			W24/25: 3.93			W24/25: Oct 24-Mar 25	W24/25: 08:30- 22:00	W24/25: Everyday	W24/25: 1082	W24/25: 100	W24/25: £13,757
			W25/26: 4.37			W25/26: Oct 25-Mar 26	W25/26: 08:30- 22:00	W25/26: Everyday	W25/26: 1234	W25/26: 100	W25/26: £13,527
			W26/27: 4.68			W26/27: Oct 26-Mar 27	W26/27: 08:30- 22:00	W26/27: Everyday	W26/27: 1333	W26/27: 100	W26/27: £13,387
			S27: 3.78			S27: Apr 27-Sep 27	W26/27: 08:30- 22:30	S27: Everyday	S27: 749	S27: 100	S27: £9,757
			W27/28: 5.13			W27/28: Oct 27-Mar 28	S27: 09:00- 20:30	W27/28: Everyday	W27/28: 1465	W27/28: 100	W27/28: £13,242
							W27/28: 00:00- 22:30				



Substation Name	Post Codes	Voltage of connection (kV)	Maximum requirement (MVA)	Need type	Delivery start date	Months required	Times required	Days required	Estimated availability hours	Estimated utilisation hours	Ceiling price (Per Annum)
Yealand	LA1 9 ,LA5 0 ,LA5 9 ,LA6 1 ,LA6 3 ,LA7 7	0.24/11kV	FY24: 3.36	Restore	01/11/2023	FY24: Apr 23-Mar 24	All Day	Everyday	N/A	FY24: 100	FY24: £25,583
			FY25: 3.36			FY25: Apr 24-Mar 25				FY25: 100	FY25: £25,583
			FY26: 3.36			FY26: Apr 25-Mar 26				FY26: 100	FY26: £25,583
			FY27: 3.36			FY27: Apr 26-Mar 27				FY27: 100	FY27: £25,583
			FY28: 3.36			FY28: Apr 27-Mar 28				FY28: 100	FY28: £25,583