



Policy Instruction. CP606 - 190718

Issued by Policy and Standards

To All Staff, Operational staff, Managers and Contractors
Authorised for Low Voltage (LV) operations requiring the
accessing of ABB and ABB Nitran LV Cabinets, Pillars and
Boards.

1. Subject

ABB and ABB Nitran LV Cabinets, Pillars and Boards.



Following a disruptive failure of an ABB LV cabinet as shown above, for which a technical investigation is currently ongoing, **the actions contained in this policy instruction shall be followed with immediate effect.** Relevant policy will be updated to reflect these changes in due course.

2. Actions to follow.

In all instances, when accessing an ABB or ABB Nitran LV cabinet, pillar or wall board, including opening or closing the door, **full LV PPE shall be worn.** This includes a full face visor, LV rubber gloves with kid leather overgloves and Arc Resistant Coverall must be used (as specified in CP606 S13 Section 1.1).

3. Issue Approval for this Policy Instruction.

This Policy Instruction has been prepared by Matthew Kayes and has been approved for Issue by Steve Cox, Engineering and Technical Director.