



## Electricity Specification xxx

Issue 1

May 2013

### LV Capacitors

#### Contents

- 1 Introduction
  - 2 Background
  - 3 Scope
  - 4 Definitions
  - 5 General Requirements for Approvals and Testing
  - 6 Requirements for Type and Routine Testing
  - 7 Conformance
  - 8 Technical Requirements
  - 9 Documentation, Training and Support
  - 10 Documents Referenced
  - 11 Keywords
- Appendix A

#### Approved for issue by the Technical Policy Panel

© 2013 Electricity North West Limited.

All Rights Reserved

The copyright of this document, which contains information of a proprietary nature, is vested in Electricity North West Limited. The contents of this document may not be used for purposes other than that for which it has been supplied and may not be reproduced, either wholly or in part, in any way whatsoever. It may not be used by, or its contents divulged to, any other person whatsoever without the prior written permission of Electricity North West Limited.



Issue and Amendment Summary

Amendment No. Date	Brief Description and Amending Action
<p>0 01/05/13</p>	<p>Issue 1 First Issue Prepared by: G M Bryson Approved by the Technical Policy Panel and signed on its behalf by Paul Whittaker:</p>



## LV CAPACITORS

### 1. INTRODUCTION

This specification describes the general and technical requirements for the provision of capacitors for use on the Low Voltage cable network in Electricity North West Limited, hereinafter referred to as Electricity North West.

### 2. BACKGROUND

As the UK economy moves towards a low carbon future the effects on the distribution networks will be varied. It is expected that demand for electricity will rise as transportation is decarbonised by electric vehicles. Further demand will result from the electrification of heating in the form of heat pumps, which are expected to replace increasingly expensive oil-fuelled and gas-fuelled heating systems. At the same time, rising retail prices and energy efficient behaviour and appliances, eg LED lighting may mitigate some of the demand increase. In addition to changes in demand, government incentives such as the feed-in-tariff will drive high penetration of various forms of generation on LV networks. These combined changes in the requirements of connected customers will introduce significant challenges for network operators.

In order to meet these changes will to networks, network operators will need to employ different techniques for voltage regulation.

The deployment of capacitors at points along LV feeders will provide Electricity North West with the opportunity to provide further voltage regulation at points closer to the consumers.

### 3. SCOPE

This specification covers the technical requirements for:

- The design, manufacture, supply and testing of a capacitor.
- The design, manufacture, supply and testing of an enclosure to contain the capacitor.

The equipment offered shall be complete in every respect with all necessary facilities and system functional requirements for reliable continuous operation.

The scope of work shall include the support and maintenance, software tools, and configuration to enable the equipment to perform as required.

The manufacturer shall supply all necessary training and maintenance tools associated with the equipment, together with logic and circuit diagrams to enable diagnosis of faults or loss of functionality that may occur in the future.

Communications with the capacitor controller shall be at the discretion of Electricity North West and dependent on geographical and network constraints. The Tenderer shall indicate if the controller is compliant with the various communication and telemetry protocols specified in the body of this document.

### 4. DEFINITIONS

**Approval:** Sanction by the Electricity North West Future Networks Technical Manager that specified criteria have been satisfied.

**Contractor:** The person or person's firm or company, including personal representatives, successors and permitted

assigns, whose tender has been accepted by Electricity North West.

<b>DNO</b>	Distribution Network Operator
<b>GPRS</b>	General Packet Radio Service
<b>iHost</b>	iHost is a brand name and provides a low cost integration platform for extension of the main SCADA to include for various remote devices
<b>SCADA</b>	Substation Control and Data Acquisition
<b>SIM</b>	Subscriber Identity Module
<b>Specification:</b>	The Specifications and schedules (if any) agreed by the parties for the purpose of the Contract.
<b>Sub-Contractor:</b>	Any person (other than the Contractor) named in the Contract for any part of the Works or any person to whom any part of the Contract has been sub-let with the consent in writing of the Engineer, and the legal representatives, successors and assigns of such person.
<b>Supplier:</b>	Any person or person's firm or company who supplies goods to Electricity North West or to its contractor.
<b>Tender:</b>	An offer in writing to execute work or supply goods at a fixed price.
<b>Tenderer:</b>	The person or person's firm or company, including personal representatives, successors and permitted assigns, invited by Electricity North West to submit a tender.

## **5. GENERAL REQUIREMENTS FOR APPROVALS AND TESTING**

### **5.1 Product not to be Changed**

No change in the product, packaging or labelling shall be made after Approval has been granted without prior notice to the Electricity North West Future Networks Technical Manager, and receipt of a written agreement to the proposed change from the Electricity North West Future Networks Technical Manager.

### **5.2 Electricity North West Technical Approval**

The tenderer shall submit, with this tender, proposals for testing which will demonstrate, to the satisfaction of the Electricity North West Future Networks Technical Manager, compliance with this Specification. Such tests shall be carried out without expense to Electricity North West.

Alternatively, the tenderer may submit technical reports and other data that he considers will demonstrate, to the satisfaction of the Electricity North West Future Networks Technical Manager, compliance with this specification. Acceptance of this evidence shall be at the discretion of the Electricity North West Future Networks Technical Manager but will not be unreasonably withheld.

Approval shall be 'factory specific' and is not transferable to another factory without the written approval of the Electricity North West Future Networks Technical Manager.

The supplier and product shall comply with all the relevant requirements of Electricity North West documents EPD311 and CP311.

### **5.3 Quality Assurance**

The tenderer shall confirm whether or not approval is held in accordance with a quality assurance scheme accredited under ISO 9000. If not, he shall submit a statement of the quality assurance procedures employed to control the quality of the product, including the performance of suppliers and sub-contractors.

The right is reserved for the Electricity North West Future Networks Technical Manager to require, from time to time, the repeat of such tests as he may deem to be reasonably necessary to demonstrate continued compliance with the specification.

The tenderer shall submit, with his tender, a list of tests and inspections which are carried out on the product prior to despatch which shall demonstrate, to the satisfaction of the Electricity North West Future Networks Technical Manager, fitness for installation and service.

The tenderer shall provide free of charge to Electricity North West such samples as may, in the opinion of the Electricity North West Future Networks Technical Manager, be reasonably required for inspection and/or retention as quality control samples. The Electricity North West Future Networks Technical Manager will confirm the requirement for samples at the time of tendering.

The right is reserved for the Electricity North West Future Networks Technical Manager to make, from time to time, such inspections of the tenderer's facilities as he may deem to be reasonably necessary to ensure compliance with this specification and any contract of which it forms a part.

The tenderer shall submit, with his tender, such details of product packaging disposal, as will enable Electricity North West to comply with the requirements of BS EN ISO 14001: 2004 - Environmental Management Systems.

### **5.4 Formulation**

The tenderer shall submit, with his tender, such details of the formulation and use of the product and associated substances as will enable Electricity North West to comply with the obligations of the Health and Safety at Work Act 1974 and the Control of Substances Hazardous to Health Regulations 2002, in the use, storage and disposal of the product. The tenderer may stipulate, prior to submission of such information, that he requires it to remain confidential and the Electricity North West Future Networks Technical Manager will, if requested, confirm his agreement to this prior to receipt of the information.

### **5.5 Identification Markings**

The tenderer shall submit, with his tender, details of markings which it is proposed to apply to the product or packaging to identify manufacturing batches or items. The forms and content of such markings shall be subject to the approval of the Electricity North West Future Networks Technical Manager, and shall in all cases include the Electricity North West approved description and commodity code number.

The tenderer shall submit, with his tender, such details of marking gross weight on components, assemblies and packages, as will enable Electricity North West to comply with the Health and Safety Manual Handling Operation Regulations 1992, for components, assemblies and packages supplied with a gross weight over 1kg. The forms and content of such markings shall be subject to the approval of the Electricity North West Future Networks Technical Manager.

## **5.6 Minimum Life Expectancy**

The minimum life expectancy of all products covered by this specification is 40 years.

## **5.7 Product Conformity**

Preference will be given to those suppliers who can provide suitable product conformity certification to a recognised or specified standard, or an equivalent certification.

## **6. REQUIREMENTS FOR TYPE AND ROUTINE TESTING**

The Electricity North West Future Networks Technical Manager shall set out the requirement of the following tests to be carried out by the supplier at the supplier's cost.

### **6.1 Requirement for Type Tests at the Supplier's Premises**

These are a series of one-off type tests, which are carried out to ensure the satisfactory performance of the product design, under extremes of operating stresses, and of endurance, as may be appropriate, to be determined by the Electricity North West Future Networks Technical Manager.

These may or may not be destructive tests.

### **6.2 Requirement for Routine Tests at the Supplier's Premises**

These tests may be required to be carried out on every individual unit or component, as specified, or at some regular frequency to be determined by the Electricity North West Future Networks Technical Manager.

The results of these tests may be required to be supplied to Electricity North West with each unit purchased or retained for inspection, at a period to be determined by the Electricity North West Future Networks Technical Manager.

## **7. CONFORMANCE**

The Tenderer shall complete the clause conformance declaration sheets in Appendix A. Failure to complete these declaration sheets may result in an unacceptable bid.

## **8. TECHNICAL REQUIREMENTS**

### **8.1 General**

Capacitor installations shall consist of three single phase capacitors connected to a LV cable and an associated controller which are housed in an enclosure installed at street level.

The capacitors shall be connected to a three phase cable termination which is connected to a cable using a standard breech joint. The capacitors and controller shall be fitted in a suitable weather and vandal proof enclosure rated to IP65 where appropriate.



Detailed specifications shall be provided by the Tenderer for all the equipment, including a layout diagram for the enclosure.

## 8.2 Failures

Tenderers shall provide validated meantime between failure data for the individual modules that make up the installation.

The data concentrator shall be designed to prevent erroneous data from being transmitted due to failure of any hardware component, failure in logic or communication channel errors.

## 8.3 Maintainability

A design that does not require periodic preventive maintenance and inspection is preferred. If periodic maintenance is required, it shall be possible to perform all such work without taking the equipment out of service.

## 8.4 Environmental Conditions

### 8.4.1 Enclosure

A weather-proof enclosure is required to house the monitoring and associated equipment. The enclosure shall not require maintenance for a period of at least 30 years in a polluted or coastal environment according to EN ISO 12944-2 Category C4.

The enclosure shall comply with IEC60529, Protection Class IP65 or better. The cabinet shall be adequately ventilated to prevent damage to any component when exposed to high ambient temperatures.

### 8.4.2 Controller

The controller communications equipment and associated supporting equipment shall be suitable for rated operation at elevations up to 1000m above sea level and shall have been type tested for continuous operation over the following environmental conditions:

- Temperature                    -20°C to +70°C
- Temperature Gradient    Up to 30°C/h
- Relative Humidity        Up to 95% at 40°C
- Cyclic Damp Heat        +40°C to +25°C at 95% Relative Humidity
- Absolute Humidity        Up to 29g/m<sup>3</sup>
- Vibration (sinusoidal)    2g acceleration 9 to 350Hz
- Shock                        15g, 11ms

All of the equipment that forms part of the complete installation shall be designed and proven to meet the requirements of the following:

- 93/68/EEC: Low Voltage Directive
- BS EN 60068: Environmental Testing
- BS EN 61000-6-2: Generic Immunity Industrial Environment

- BS EN 55022 (Class B): Radio Disturbance Conducted & Radiated (installed in enclosure)

## **8.5 Immunity from Electromagnetic Interference, Radiated Disturbance and Electrostatic Discharge**

The electrical and electronic components of all equipment shall satisfy the appropriate requirements for insulation, isolation, and immunity from electromagnetic interference, radiated disturbance and electrostatic discharge.

The controller, communications equipment and cabinet shall be designed for safe operation in the harsh environment encountered in remote locations with high voltage plant.

Data communication ports shall be demonstrated to withstand disturbance test without permanent corruption of data, and subsequent delay of data transfer.

## **8.6 Enclosure Construction**

The enclosure shall be suitable for installation in the public highway. The dimensions of the enclosure shall be as small as possible so as to have the minimum impact on the environment around the consumer's premises.

The construction of the cabinet shall be in accordance with the relevant electrical engineering standards detailed in this specification and in accordance with the latest edition of BS 7671, Electricity at Work Act and any current legislative requirements.

All measures shall be taken to prevent the ingress of moisture and the occurrence of corrosion on any part of the monitoring equipment, located within the cabinet.

The cabinet shall be lockable and vandal-proof. Locking arrangements for the cabinets shall be via the use of a hasp and staple to fit Electricity North West standard distribution substation door padlocks as per ES309. The locking point shall be suitably shrouded to prevent access to the hasp. A suitable door stay shall be fitted, with a positive opening feature, to hold the door open at 90°.

Suitable removable lifting eyes shall be provided.

The manufacturer shall fit the Electricity North West property plate and danger of death signs as per Electricity Specification ES356 to the door of the enclosure. Suitable fixing points shall also be provided to allow for the fitting of a site specific nameplate by Electricity North West.

A means of LV power isolation shall be provided to enable maintenance to be safely carried out within the cabinets.

Any ancillary items or requirement for the cabinets such as heaters, lighting, fixtures and fittings etc. shall be included.

## **8.7 Capacitor**

### **8.7.1 Rating**

The tenderer shall provide the necessary technical and pricing details for capacitors of sizes 50kVAr, 100kVAr, 150kVAr and 200kVAr.

### **8.7.2 Controller**

The controller shall sense the line voltage and switch in the capacitor unit to flatten the voltage profile when the voltage drops below a preset threshold. It shall be possible to alter this threshold both locally and remotely.

### **8.7.3 Remote Operation**

The controller shall have GPRS communications as a minimum although alternative communications may be considered for the future evolution of the system to allow for remote operation. The Tenderer shall detail the available communications options.

Where GPRS communications are included Electricity North West shall issue SIM cards. If this is likely to cause any problems then these shall be identified.

The Tenderer shall state which communications protocol can be used.

Electricity North West uses the iHost SCADA platform (as provided by Nortech) and it is preferable that communications from site is direct to Electricity North West's iHost system. The Tenderer shall state if their proposed solution is compatible with iHost and if not, details shall be provided on how compatibility can be achieved.

### **8.7.4 Protection**

The protection shall be arranged so that loss of a single phase shall cause all 3 capacitors to be isolated from the network.

### **8.7.5 Discharge**

The tenderer shall provide details on how the capacitor is to be discharged before any work commences.

### **8.7.6 Energy Consumption**

The tenderer shall provide details on the energy consumption of the product as well as the carbon footprint of the company.

## **8.8 Installation**

The capacitor shall be capable of being installed and commissioned without the need for a customer shutdown.

Due regard shall be given to any hard wiring between the voltage termination and the capacitor regarding the need to provide isolation and fusing.

The Tenderer shall provide details of any additional items that will need to be procured by Electricity North West in order to fully install the capacitors.

## **9. DOCUMENTATION, TRAINING, AND SUPPORT**

The supplier shall be available to support the installation of the capacitor and where appropriate the commissioning of the data interfaces into Electricity North West's iHost platform.

The supplier shall provide any necessary training of installation and operating personnel.

A copy of the installation and configuration manual for the system shall be provided.

The supplier shall provide details of any diagnostics or maintenance requirements. If this can be carried remotely, details shall be provided so that Electricity North West can investigate the implementation into existing systems.

## 10. DOCUMENTS REFERENCED

Health and Safety at Work Etc Act 1974

Electricity at Work Regulations 1989

Control of Substances Hazardous to Health Regulations 2002

Manual Handling Operations Regulation 1992

93/68/EEC                      Low Voltage Directive

BS EN 55022                    Information Technology Equipment - Radio Disturbance  
Characteristics - Limits and Methods of Measurement

BS EN 60068                    Environmental Testing

BS EN 60439                    Low-voltage Switchgear and Controlgear Assemblies

BS EN 60529                    Degrees of Protection provided by Enclosures (IP Code)

BS EN 60870                    Telecontrol Equipment and Systems

BS EN 61000                    Electromagnetic Compatibility (EMC)

BS EN ISO 9000                Quality Management Systems

BS EN ISO 14001              Environmental Management Systems

BS 7671                         IET Wiring Regulations

EPD311                         Approval of Equipment

CP311                         Equipment Approval Process

ES309                         Substation Locking

ES356                         Notices and Nameplates

## 11. KEYWORDS

Capacitor; LV.

**APPENDIX A**  
**SELF CERTIFICATION CONFORMANCE DECLARATION**  
**SECTION BY SECTION CONFORMANCE WITH SPECIFICATION**

The manufacturer shall declare conformance or otherwise, section by section, using the following levels of conformance declaration codes.

Conformance Declaration Codes

- N/A = Section is not applicable/appropriate to the product/service
- C1 = The product/service conforms fully with the requirements of this section
- C2 = The product/service conforms partially with the requirements of this section
- C3 = The product/service does not conform to the requirements of this section
- C4 = The product/service does not currently conform to the requirements of this section, but the manufacturer proposes to modify and test the product in order to conform.

**Manufacturer:**

**Product/Service Description:**

**Product/Service Reference:**

Assessor

**Name:**

**Company:**

**Signature:**

**Date:**

Section	Section Topic	Conformance Code	Remarks (Must be completed if Conformance Code is not C1)
3	Scope		
5.1	Product not to be Changed		
5.2	Electricity North West Technical Approval		
5.3	Quality Assurance		
5.4	Formulation		
5.5	Identification Markings		
5.6	Minimum Life Expectancy		
5.7	Product Conformity		
6.1	Requirements for Type Tests at the Supplier's Premises		
6.2	Requirement for Routine Tests at the Supplier's Premises		
7	Conformance		
8.1	General		
8.2	Failures		
8.3	Maintainability		
8.4.1	Environmental - Enclosure		
8.4.2	Environmental – Controller		

Section	Requirement	Conformance Code	Remarks (Must be completed if Conformance Code is not C1)
8.5	Immunity from Electromagnetic Interference, Radiated Disturbance and Electrostatic Discharge		
8.6	Enclosure Construction		
8.7.1	Capacitor - Rating		
8.7.2	Capacitor – Protection		
8.7.3	Capacitor – Energy Consumption		
8.7.4	Capacitor – Remote Operation		
8.8	Installation		
9	Documentation, Training and Support		

Additional Notes: